



cogta

Department:
Co-operative Governance and Traditional Affairs
PROVINCE OF KWAZULU-NATAL

PROJECT: DEVELOP A UNIVERSAL ACCESS PLAN ACROSS FIVE DISTRICT MUNICIPALITIES IN KZN



A Division of the Crowie Property Group



[REPORT: DEVELOPMENT OF UNIVERSAL ACCESS PLAN FOR WATER SERVICES FOR UGU DISTRICT MUNICIPALITY]



REPORT TITLE	Development of Universal Access Plan for Water Services in Ugu District Municipality		
CLIENT	Department of Cooperative Governance and Traditional Affairs		
FOCUS	Prepared by : _____	Reviewed by: _____	Approved by: _____
MM PDNA	Prepared by : _____	Reviewed by: _____	Approved by: _____
MHP GEOSPACE	Prepared by : _____	Reviewed by: _____	Approved by: _____

DESCRIPTION	REVISION	DATE
Ugu District Municipality Universal Access Plan	Final	07/10/2014

TABLE OF CONTENTS

1.	Executive Summary	6
2.	Introduction	13
2.1	Background of the study	13
2.2	Ugu District Municipality Overview	14
2.2.1	Vulamehlo LM (KZ 211)	15
2.2.2	Umdoni LM (KN 212)	16
2.2.3	Umzumbe Local Municipality (KZ 213)	17
2.2.4	Umuziwabantu Local Municipality (KZ 214)	18
2.2.5	Ezingoleni LM (KZ 215)	19
2.2.6	Hibiscus Coast Local Municipality (KZ 215)	20
3.	Assesment of Water Planning Status Quo	21
4.	Develop Continuous Water Supply footprint areas	22
4.1	Verification of existing information received from the UDM	26
5.	Existing Water Supply Schemes	27
5.1	Water Resources	27
5.1.1	Rivers	27
5.1.2	Dams	28
5.1.3	Existing Water Schemes	28
6.	Reconciliation of existing and proposed water supply and demand options	64
6.1	Existing Water and Sanitation Infrastructure	68
6.2	Water and Sanitation Backlogs	68
7.	Proposed Future Supply Options	69
7.1	Existing proposals for future supply	69
8.	Approach to Water Supply	82
8.1	Water Treatment Works Situation Analysis	82
8.2	Design Parameters	84
8.3	Scheme Types	84
8.3.1	Link to existing scheme	85
8.3.2	Refurbishment of mechanical boreholes	86
8.3.3	Refurbishment of electrical boreholes	87
8.3.4	New mechanical boreholes	88
8.3.5	New electrical boreholes	89
8.3.6	Existing Scheme pumped to new elevated tank and reticulated	90
8.3.7	New Package Water Treatment Works	91

8.4	Description and mapping of supply schemes	93
8.5	Cost Estimates for Proposed Infrastructure	95
8.5.1	Proposed Short Term Supply Schemes	98
8.5.2	Proposed Long Term Supply Schemes	101
8.6	Phasing of scheme options	103
9.	Develop an updated geo database including meta data of all relevant information	105
10.	Conclusion And Recommendations	106
10.1	Total cost of proposed schemes in the Ugu District Municipality	106
10.2	Total cost of phases of schemes in the Ugu District Municipality	106
10.3	Proposed Future Work.....	107
11.	Annexures.....	108
12.	Acknowledgement and Disclaimer.....	128

INDEX OF FIGURES

Figure 1 – Ugu District Municipality Locality Map	14
Figure 2 - Vulamehlo Local Municipality.....	15
Figure 3 - Umdoni Local Municipality	16
Figure 4 – Umzumbe Local Municipality.....	17
Figure 5 - Umuziwabantu Local Municipality.....	18
Figure 6 - Ezingoleni Local Municipality.....	19
Figure 7 - Hibiscus Coast Local Municipality	20
Figure 8 – Schematic layout of Kwalembe Water Supply Scheme area	31
Figure 9 – Schematic layout of Ndelu Water Supply Scheme area.....	35
Figure 10 – Schematic layout of Pungashe Water Supply Scheme area.....	39
Figure 11 – Schematic layout of Umtamvuna Water Supply Scheme area	43
Figure 12 – Schematic layout of Mtwalume Water Supply Scheme area.....	47
Figure 13 – Schematic layout of Lower Umzimkhulu Water Supply Scheme area	51
Figure 14 – Schematic layout of Umzinto Water Supply Scheme area	55
Figure 15 – Schematic layout of Vulamehlo Water Supply Scheme area.....	59
Figure 16 – Schematic layout of Weza Water Supply Scheme area	63
Figure 17 – Ugu District Planned & Currently Under Construction Water & Sanitation Projects	74
Figure 18 – Ugu District Completed & Existing Projects	75
Figure 19 - Existing Borehole Schemes not in operation	85

LIST OF TABLES

Table 1 – Existing Water Resources	27
Table 2 - Water Treatment Works in operation in the Kwalembe Water Supply Scheme area.....	29
Table 3 - Water Treatment Works in operation in the Ndelu Water Supply Scheme area	34
Table 4 - Water Treatment Works in operation in the Pungase Water Supply Scheme area	37
Table 5 - Water Treatment Works in operation in the Umtamvuna Water Supply Scheme area.....	41
Table 6 - Water Treatment Works in operation in the Mtwalume Water Supply Scheme area	45

Table 7 - Water Treatment Works in operation in the Umzimkhulu Water Supply Scheme area	49
Table 8 - Water Treatment Works in operation in the Umzinto Water Supply Scheme area	53
Table 9 - Water Treatment Works in operation in the Vulamehlo Water Supply Scheme area	57
Table 10 - Water Treatment Works in operation in the Weza Water Supply Scheme area	61
Table 11 – Example of household data with unique water supply footprint identifier	64
Table 12 – Example of low and high household and population statistics	66
Table 13 - Summary of water infrastructure components	68
Table 14 - Existing Sanitation Infrastructure.....	68
Table 15 - Water Backlogs.....	68
Table 16 - Sanitation Backlogs	69
Table 17 – Projects/programmes for water supply projects	73
Table 18 - Phasing of Schemes.....	104

LIST OF REFERENCES

Department of Water Affairs. (2011). *First Stage Reconciliation Strategy for Kwalembe Water Supply Supply Scheme Area - Vulamehlo Local Municipality.*

Department of Water Affairs. (2011). *First Stage Reconciliation Strategy for Mtwalume Water Supply Supply Scheme Area -Umzumbe Local Municipality.*

Department of Water Affairs. (2011). *First Stage Reconciliation Strategy for Ndelu Water Supply Supply Scheme Area - Umzumbe Local Municipality.*

Department of Water Affairs. (2011). *First Stage Reconciliation Strategy for Pungashe Water Supply Supply Scheme Area -Umzumbe Local Municipality.*

Department of Water Affairs. (2011). *First Stage Reconciliation Strategy for Umtamvuna Water Supply Supply Scheme Area - Hibiscus Coast Local Municipality.*

Department of Water affairs. (2011). *First Stage Reconciliation Strategy for Umzimkulu Water Supply Supply Scheme Area - Umzimkulu Local Municipality.*

Department of Water Affairs. (2011). *First Stage Reconciliation Strategy for Umzinto Water Supply Supply Scheme Area - Umdoni Local Municipality.*

Department of Water Affairs. (2011). *First Stage Reconciliation Strategy for Vulamehlo Water Supply Supply Scheme Area - Vulamehlo Local Municipality.*

Department of Water Affairs. (2011). *First Stage Reconciliation Strategy for Vulamehlo Water Supply Supply Scheme Area - Vulamehlo Local Municipality.*

Department of Water Affairs. (2011). *First Stage Reconciliation Strategy for Weza Harding Water Supply Supply Scheme Area - Umuzwabantu Coast Local Municipality.*

Ezinqoleni Local Municipality. (2013-2014). *Ezinqoleni Local Municipality Intergrated Development Plan.*

Hibiscus Coast Local Municipality. (2013-2014). *Hibiscus Coast Local Municipality Intergrated Development Plan*.

Statistics South Africa. (n.d.). *Statistics South Africa*. Retrieved from www.statssa.gov.za

Ugu District Municipality. (2008). *Ugu District Municipality Water Services Development Plan*.

Ugu District Municipality. (2013-2014). *Ugu District Municipality Intergrated Development Plan*.

Umdoni Local Municipality. (2013-2014). *Umdoni Local Municipality Intergrated Development Plan*.

Umziwabantu Local Municipality. (2013-2014). *Umziwabantu Local Municipality Intergrated Development Plan*.

Umzumbe Local Municipality. (2013-2014). *Umzumbe Local Municipality Intergrated Development Plan*.

Vulamehlo Local Municipality . (2013-2014). *Vulamehlo Local Municipality Intergrated Development Plan*.

GLOSSARY

COGTA	-	Department of Cooperative Governance and Traditional Affairs
DM	-	District Municipality
DRDLR	-	The Department of Rural Development and Land Reform
DWA	-	Department of Water Affairs
GIS	-	Geographical Information System
IDP	-	Integrated Development Plan
LM	-	Local Municipality
MIG	-	Municipal Infrastructure Grant
PIG	-	Provincial Infrastructure Grant
PMU	-	Project Management Unit
RWSS	-	Regional Water Supply Scheme
TA	-	Traditional Authorities
TOR	-	Terms of reference
UAP	-	Universal Access Plan
UDM	-	Ugu District Municipality
WARMS	-	Water Authorisation and Registration Management System
WSA	-	Water Services Authority
WSDP	-	Water Services Development Plan
WSP	-	Water Services Provider
WTW	-	Water Treatment Works
WWTW	-	Waste Water Treatment Works
WUA	-	Water User Association

1. EXECUTIVE SUMMARY

The consortium consisting of Focus, Mott Macdonald PDNA, MHP GeoSpace and Sivuno Consulting were appointed to undertake the Universal Access Plan (UAP) for water in five of the District Municipalities in KwaZulu- Natal. The report was to focus on the following:

- Assessment of water planning status quo.
- Identify existing water supply schemes.
- Identify already proposed future water supply schemes (at a conceptual level).
- Existing and proposed water supply and demand options.
- An updated geo database.
- Preparation of a Universal Access Plan (UAP) which entails collection of infrastructure backlog, verification of existing data from the various municipalities and formulating a plan with relevant milestones and associated costs to achieve Universal Access.

The following documents were viewed for information regarding the water planning status quo and assessment of all existing supply schemes as well as proposed future supply options for each of the Local Municipalities and the District Municipality:

Documents	Latest Report
Ugu District Municipality Integrated Development Plan	2013
Vulamehlo Local Municipality Integrated Development Plan	2013
Umdoni Local Municipality Integrated Development Plan	2013
Umzambe Local Municipality Integrated Development Plan	2013
Umizwabantu Local Municipality Integrated Development Plan	2013
Ezingoleni Local Municipality Integrated Development Plan	2013
Hibiscus Coast Local Municipality Integrated Development Plan	2013
Water Services Development Plan	2008
Development of Water Reconciliation Strategy for all towns in the Eastern Region for Ugu District Municipality	2011
Department of Water Affairs Priority Projects	2011

The methodology applied in the development of a Universal Access Plan for Water Services in Ugu District Municipality was as follows:-

- MM PDNA arranged meetings with the technical staff of the Ugu District Municipality in order to obtain GIS information and confirm the water backlog data, as well as confirm existing and proposed schemes in the Ugu District Municipality.
- MHP GeoSpace obtained Geographic Information System (GIS) spatial information from various sources, including the Ugu District Municipality and the Department of Water Affairs. All data has been stored in an ESRI ArcGIS 10.1 relational geodatabase, using a geographic co-ordinate system (decimal degrees). Metadata has been captured for all the data within the geodatabase. Domains or look-up tables have also been included to ensure consistency in data capture across all areas, and by all users.

- Draft water supply footprints were digitised off the latest colour aerial photography available from the Department of Rural Development and Land Reform. These were captured as polygons following settlement boundaries, and using existing water infrastructure where available. Settlement boundary datasets from the Department of Water Affairs and the Department of Rural Development and Land Reform, together with household points from Eskom (captured in 2011), were used as informants in this process. Outlying households were incorporated where possible but this was not always achievable in cases of isolated households that were located away from the more densely settled areas. In some cases these isolated households consisted of independent, privately owned farms which have their own local supply. These were excluded from the water supply footprint.
- A web mapping application was developed for the District, and served on the internet using ArcGIS Server, from the ESRI suite of GIS software products. This allowed users to view the data in their particular area, and where possible, to identify gaps in the data which could then be addressed by the project team. The engineering team had editing capabilities on this website and were able to identify and edit the attributes of any of the water supply footprints, to edit their shape if necessary, or to capture completely new water supply footprints in any area. Often these consisted of Independent farm houses with their own local supply, which were excluded from the water supply footprint.
- GIS analysis was used to calculate the high and low household numbers, as well as the high and low population counts, for each of the water supply footprints. Statistics SA were consulted on the best method in which to do this, and their census data was used to calculate the average growth rate per annum between 2001 and 2011. This data was applied to calculate the population in 2014 for each polygon. The same growth rate was applied to the number of households, which was calculated from the Eskom 2011 household point data. The table below indicates the growth rate for the Ugu District Municipality.

Census Year	1996	2001	2011	% Growth from 1996 - 2001	% Growth from 2001 - 2011	% growth pa (1996 - 2001)	% growth pa (2001 - 2011)
Ugu	641491	704030	722484	9.7	2.6	1.9	0.3

- The levels of service (LOS) points, supplied by the Department of Water Affairs, were mapped along with the water supply footprints. These were used to indicate which households were currently supplied with water services, and those which were not yet serviced and needed schemes to be implemented.

The water backlogs in the Ugu District Municipality are presented in the table below.

Local Municipality	Backlogs (Households)
Vulamehlo	3420
Umdoni	837
Umzumbe	7080
Umizwabantu	2296
Ezingoleni	873
Hibiscus Coast	2034
Ugu	16540

- The highest number of households for each water supply footprint (whether from 2011 or 2014) was used to calculate current, future and probable water demand requirements, measured in million m³ per annum.
- Map series at a scale of 1:20 000 were printed of the entire District Municipality, and these were given to MM PDNA so that conceptual water supply schemes could be designed. These designs were then returned to the GIS team, and captured into the geodatabase.
- Once the concept plans had been captured, they were checked for connectivity between adjacent municipalities. Attribute data, where available, was added to the geodatabase.
- Ownership information was added to each footprint polygon, using cadastral from the Surveyor-General and ownership data from the Deeds office. As the polygons did not follow cadastral boundaries, but rather the actual settlement points, the centroid of each footprint was used to determine the ownership of the property at that location. Ownership was divided into private, non-private (which included national, provincial and local municipal ownership) and land owned by the Ingonyama Trust Board.
- Each water supply footprint was checked against existing water infrastructure data to determine whether there was, or was not, short term water supply in the area.

LOCAL MUNICIPALITY	NO OF WATER SUPPLY FOOTPRINTS	NO OF WATER SUPPLY FOOTPRINTS WITH SHORT TERM SUPPLY
Vulamehlo	36	22
Umdoni	24	22
Umzumbe	34	27
Umizwabantu	36	27
Ezingoleni	9	6
Hibiscus Coast	34	32
Ugu	173	136

- MM PDNA undertook the conceptual design based on the water supply footprints provided by MHP GeoSpace. Where possible the concept designs were tied into the Ugu District Municipality's planned network to avoid any duplication of infrastructure and to reduce costs.

The following assumptions were made in undertaking the conceptual designs for the un-serviced population:

- Water consumptions were based in accordance to the table below:

Description of consumer category	Household Annual Income range	Per capita cons (l/c/d)		
		Min	Ave.	Max.
Very High Income; villas, large detached house, large luxury flats	>R1 228 000	320	410	500
Upper middle income: detached houses, large flats	153 601 – 1 228 000	240	295	350
Average Middle Income: 2 - 3 bedroom houses or flats with 1 or 2 WC, kitchen, and one bathroom, shower	38 401 – 153 600	180	228	275
Low middle Income: Small houses or flats with WC, one kitchen, one bathroom	9 601– 38 400	120	170	220
Low income: flatlets, bedsits with kitchen & bathroom, informal household	1- 9600	60	100	140
No income & informal supplies with yard connections		60	70	100
Informal with no formal connection		30	70	70
Informal below 25 l/c/d		0	70	70

- Each household has an average of 6 people
 - Some of the existing boreholes are functional.
 - The existing water reticulation schemes are operational.
 - Some of the existing water reticulation schemes have spare capacity.
 - Existing water treatment works have the potential to be upgraded or rehabilitated.
 - Schemes have some form of power supply.
 - General pipe size range is from 25 mm to 150 mm diameter.
 - Peak factor - 1.5
 - Water losses were considered to be 35%
 - Where there is an existing bulk line, connections to the bulk were kept to a minimum
 - Reticulation mains were placed in the road reserve for maintenance purposes.
 - District and provincial road crossings were kept to a minimum
- In viewing the water supply footprints on the GIS mapping the following parameters were used by MM PDNA to determine the type of scheme applicable to the different water supply footprints. The following scheme types were considered in the conceptual designs:
 - Tie into existing schemes
 - Existing boreholes and standpipes that are non-functional to be rehabilitated.
 - Existing boreholes with reticulation to be rehabilitated.
 - Boreholes mechanically operated for settlements with a low population.
 - Boreholes electronically operated for settlements with a high population.

- Package Plants for settlements which are densely populated.
- From existing scheme pumped to new reservoir and reticulated.

Schematics and a detailed description of the various scheme types indicated above are indicated later in this document.

- The conceptual designs were quantified according to scheme types and the rates for various components of the water reticulation were provided by Umgeni Water and are stated in the document.

The conceptual designs and cost estimates for each of the local municipalities as well as the district municipality and based on the various schemes are summarized in the following tables. The detailed costs for each scheme type are indicated in section 8.5 of this document.

Vulamehlo LM	
Scheme Type	Total
Link to Existing Scheme	R 291 160 632
New boreholes mechanically operated	R 5 881 260
New boreholes electronically operated	R 9 652 359
TOTAL	R 306 694 251

Umdoni LM	
Scheme Type	Total
Link to Existing Scheme	R 41 554 530
TOTAL	R 41 554 530

Umzumbe LM	
Scheme Type	Total
Link to Existing Scheme	R 443 303 125
TOTAL	R 443 303 125

Umuziwabantu LM	
Scheme Type	Total
Link to Existing Scheme	R 173 793 594
New boreholes electronically operated	R 9 169 825
TOTAL	R 182 963 419

Ezingoleni LM	
Scheme Type	Total
Link to Existing Scheme	R 220 519 973
New boreholes electronically operated	R 3 285 706
TOTAL	R 223 805 679

Hibiscus Coast LM	
Scheme Type	Total
Link to Existing Scheme	R 217 662 386
TOTAL	R 217 662 386

The following table is a summary of all the local municipalities in the Ugu District Municipality for the various scheme types, and illustrates the total estimated cost for the District Municipality.

Ugu DM	
Scheme Type	Total
Link to Existing Scheme	R 1 387 994 240
New boreholes mechanically operated	R 5 881 260
New boreholes electronically operated	R 22 107 890
TOTAL	R 1 415 983 390

- The table below indicates the backlogs in the Ugu District Municipality and the cost per capita to eradicate the current backlog.

Local Municipality	Backlogs (Households)	Cost per capita
Vulamehlo	3420	R 14 946
Umdoni	837	R 8 274
Umzumbe	7080	R 10 436
Umziwabantu	2296	R 13 281
Ezingoleni	873	R 42 727
Hibiscus Coast	2034	R 17 835
Ugu	16540	R 14 268

- The phasing of schemes is based on the proposed plans which cover all reticulation and bulk supplies to address the water backlogs. Potential funding such as Municipal Infrastructure Grant (MIG), Provincial Infrastructure Grant (PIG), Cooperative Governance and Traditional Affairs (COGTA), Department of Water Affairs and Forestry (DWAF) etc may be applied for to undertake these projects. The table below indicates the phasing.

An average cost for each scheme type was compared with the cost estimate for an individual scheme. If the scheme was less than or equal to the average it was assumed that the project could be undertaken over a year. If the cost ratio was higher than the average cost, the ratio was used to determine the duration of the project. However, this is flexible depending on the nature and type of project.

Implementation Year	LM	Total Cost
2015/16	Vulamehlo	R 210 000 628
	Umdoni	R 9 912 780
	Umzumbe	R 113 904 727
	Umuziwabantu	R 85 534 954
	Ezingoleni	R 89 912 206
	Hibiscus Coast	R 130 458 982
	TOTAL	R 639 724 277

Implementation Year	LM	Total Cost
2016/17	Vulamehlo	R 40 246 448
	Umdoni	R 31 641 751
	Umzumbe	R 210 784 920
	Umuziwabantu	R 97 428 465
	Ezingoleni	R 133 893 472
	TOTAL	R 513 995 056

Implementation Year	LM	Total Cost
2017/18	Vulamehlo	R 56 447 175
	Umzumbe	R 118 613 477
	TOTAL	R 175 060 652

Implementation Year	LM	Total Cost
2018/19	Hibiscus Coast	R 87 203 404
	TOTAL	R 87 203 404

- In the Ugu District Municipality, it is estimated that the existing water backlog of 16540 households can be eradicated by 2019 at a cost of R 1 415 983 390 to develop 59 schemes.
- All GIS data, including all current infrastructure, together with proposed schemes and the costs thereof have been incorporated into a structured geodatabase, with all relevant metadata. In some cases, metadata has also been captured for individual fields within particular datasets.

2. INTRODUCTION

2.1 Background of the study

In terms of the Department of Cooperative Governance and Traditional Affairs (COGTA) strategic priorities 2013/14 Programme 3 (Development Planning), the Department must prepare a UAP (Universal Access Plan) with a specific focus on water, sanitation and electricity as contained in the MEC's 2013/14 Vote 11 Budget Speech of the 30th of May 2013.

The intention of the UAP is to create service delivery liberated zones. A significant number of municipalities in KwaZulu-Natal are close to achieving universal access in key municipal infrastructure services such as water, sanitation and electricity.

Hence there is a need to formulate a plan to quantify remaining backlogs and the cost thereof.

As a result, the Municipal Infrastructure Development Business Unit of the KwaZulu - Natal Province Department of COGTA required the Focus Consortium to undertake the collection of infrastructure backlog data, verify data and compile a UAP document with relevant milestones and associated costs. The resources were selected in terms of the TOR (terms of reference) from all service providers from the PMU (Project Management Unit), provided that the requirements are met.

The consortium consisting of Focus, Mott Macdonald PDNA, MHP GeoSpace and Sivuno Consulting, and were appointed to undertake the UAP for water in five of the District Municipalities in KwaZulu-Natal. The report was to focus on the following:

- Assessment of water planning status quo.
- Identify existing water supply schemes.
- Identify already proposed future water supply schemes (at a conceptual level).
- Existing and proposed water supply and demand options.
- An updated geodatabase.
- Preparation of a UAP which entails collection of infrastructure backlog, verification of existing data from the various municipalities and formulating a plan with relevant milestones and associated costs to achieve a UAP.

2.2 Ugu District Municipality Overview

Ugu District Municipality (UDM) is one of the ten district municipalities in the province. It is 5 866 km² in extent and has a coastline which extends for 112 km, which forms its eastern border. The region is bordered on the north by the EThekweni Municipality, in the west by Umgungundlovu District Municipality and Sisonke District Municipality and on the southern side it borders with the Eastern Cape Province.

The municipality consists of eighty one municipal wards, which culminate into six local municipalities (LM), namely Hibiscus Coast (KZ 216), Ezingoleni (KZ 215), Umuziwabantu (KZ 214), Vulamehlo (KZ 211), Umzumbe (KZ 213) and Umdoni (KZ 212). The region also boasts forty two traditional authorities. According to the Household Survey Data, Statistics SA (2011) UDM has a population of 722484.




Figure 1 – Ugu District Municipality Locality Map

The following are the local municipalities situated in the UDM:

2.2.1 Vulamehlo LM (KZ 211)

The Vulamehlo LM forms part of the UDM. It is located south of the eThekweni municipality and is bordered by Umdoni to the east, Mkhambathini and Richmond to the north and Ubuhlebezwe to the west. It covers a geographical area of 960 km². It has a population of approximately 77403.

The Vulamehlo Municipality comprises of eight traditional areas under the Vulamehlo House of Traditional leadership made up of Izimpethu Zendlovu, Mandleni, KwaLembe, AmaNyuswa, Qiko, Zembeni, Kwa-Cele and Ukuthula. There are, however, three other traditional houses which form part of Umbumbulu Traditional house namely Thoyana, Maphumulo and Isimahla traditional houses also forming part of the Vulamehlo LM.




Figure 2 - Vulamehlo Local Municipality

2.2.2 Umdoni LM (KN 212)

Umdoni LM is located in KwaZulu-Natal within the UDM. The LM consists of 10 wards with a geographical area of 238 km². The municipality comprises of 10 municipal wards. The municipality incorporates 07 Traditional Authority (TA) areas comprising 10 municipal wards. The Umdoni LM covers a geographical area of 252 km² and has a total population of approximately 78875.

There are three Traditional Council areas in Umdoni LM which are: Shozi TA-Langa /Emalangeni, Cele TA, Zembeni TA.




Figure 3 - Umdoni Local Municipality

2.2.4 Umuziwabantu Local Municipality (KZ 214)

The Umuziwabantu LM is located on the western boundary of the UDM and shares its borders with the Eastern Cape; Sisonke District and to the east with the Umzambe and Ezingolweni Municipalities. The extent of the Umuziwabantu Municipal area is 1088 km².

This area is constituted as follows: Farmlands, Urban, Tribal, and Forestry. Umuziwabantu LM consists of 10 wards with six tribal authorities which include KwaFodo TA, KwaMbotho TA and Thokozani Madumisa TA, Bashaweni TA, Izibonda TA and Inhlangano TA and has a total population of 96556.




Figure 5 - Umuziwabantu Local Municipality

2.2.5 Ezingoleni LM (KZ 215)

Ezingoleni LM is one of the six local municipalities that form part of the UDM. This municipality is located on the south-western boundary of the UDM, adjacent to the west of the Hibiscus Coast LM and east of the Umuziwabantu LM. The Ezingoleni Municipal area is 649 km² with a population of approximately 52540.

The institutional and spatial make up of Ezingoleni Municipality is fundamentally informed by three traditional authority areas, namely: KwaNyuswa, KwaMthimude and KwaVukuzithathe.




Figure 6 - Ezingoleni Local Municipality

2.2.6 Hibiscus Coast Local Municipality (KZ 215)

The Hibiscus Coast LM is located on the South Eastern part of KwaZulu Natal. It runs along the coastal belt stretching from Hibberdene to Port Edward and about 30km into the interior. It has a population of 256135 and it covers approximately 837km² in geographic area.

It consists of 29 wards, six town centres and six traditional authority areas. The traditional areas include; KwaXolo; KwaNzimakwe; KwaNdwalane; KwaMadlala; KwaMavundla; and KwaLushaba. The town centres include; Port Shepstone, Port Edward, Margate, Hibberdene and Shelly Beach.

The towns are located along the urban strip and the traditional areas in the hinterland or the south western side of the Municipality. The Indian Ocean borders the Eastern part of the Municipality, while on the Southern part runs Umtamvuna River which is the boundary between KZN and the Eastern Cape. Ezingoleni Municipality borders the north-western part while Umzumbe Municipality borders the northern part while Umdoni Municipality is on its north-eastern boundary.




Figure 7 - Hibiscus Coast Local Municipality


3. ASSESSMENT OF WATER PLANNING STATUS QUO

In order to assess the current water and sanitation situation in Ugu District Municipality, data in the form of Geographic Information System (GIS) spatial information was obtained from various sources, among them the Department of Water Affairs (DWA) and Ugu District Municipality.

All spatial data has been stored in an ESRI ArcGIS 10.1 relational geodatabase. Due to the spatial location of the five District Municipalities in which work was undertaken, all data was stored in a geographic co-ordinate system i.e. decimal degrees. Where necessary, source data has been projected to the required co-ordinate system. Metadata (information about the data – e.g. source, date, capture method) has been captured within the geodatabase.

The geodatabase also includes base data such as boundaries, roads and place names, as well as household points from the Eskom study of 2011. Domains within the geodatabase behave as look-up tables, which allow the user to update the data using specific values. This ensured consistency in data capture across all team members and across all areas in terms of the way data was captured, as well as the type of data captured.

Domains include the bulk water classification, type and condition, together with the water scheme name and maintenance requirements. Domains can be edited and updated to allow for changes in users and projects. Once all currently available data had been collated, the district municipality was contacted to see if there was any additional data that could be obtained and added to the database. Ugu District Municipality provided the project team with all data that was available and this data has been incorporated into the mapping and design of the proposed schemes.




Map 1 – Example of water infrastructure in the Umzinto area

4. DEVELOP CONTINUOUS WATER SUPPLY FOOTPRINT AREAS

After consultation with Umgeni Water, water supply footprints in the District Municipality were captured as polygons tightly following the edge of settled areas. The data was captured on screen through heads-up digitising against the latest colour aerial photography (ranging from 2009 – 2011) available from the Department of Rural Development and Land Reform. The scale of capture was 1: 10 000, with 1: 5000 capture being done in dense areas.

Areas for capture were identified primarily using the Eskom 2011 household point data, together with additional settlement information (DWA settlements; Department of Rural Development and Land Reform settlements) and existing infrastructure data. These were overlaid onto aerial photography, and polygons were created around obvious settled areas. Outlying households were incorporated where possible but this was not always achieved in cases of isolated households that were far away from more densely settled areas. Once the above data sources had been exhausted, the whole district was panned through and any additional settlements were picked up from the aerial photography.

These water supply footprints were captured over the whole district, including areas where there was existing infrastructure and/or supply




Map 2 – Water Supply Footprint with existing water reticulation



Map 3 – Water Supply Footprint where no water reticulation exists


An example of the differences between the settlement boundary datasets is illustrated in Map 4 . There were areas where the boundaries between the datasets were co-incident (the blue lines lie over the red lines), as well as areas where the datasets differ.




Map 4 – Example of settlement boundary datasets

Database fields were added to the attribute listing as per the attributes stipulated by Umgeni Water. A detailed list and descriptions of these fields can be found in Annexure A.

Due to the time constraints of this project, and in an effort to make as much data as possible available to both the project team, and the District Municipality, a web mapping application was developed for the District, and served on the internet using ArcGIS Server, from the ESRI suite of GIS software products. This allowed users to view the data in their particular area, and where possible, to identify gaps in the data which could then be addressed by the project team. The water demand area polygons captured in the desktop study were included in this application.



Map 5 – Screenshot of the web mapping application



Map 6 – Screenshot of the editor capability on the web mapping application

The engineers from Mott Macdonald PDNA (MM PDNA) were given editing capabilities to the water supply footprint layer on the website. This allowed them to identify and edit the attributes of any of these areas, to edit their shape if necessary, or to capture completely new areas at any location. These online edits were written back to the base database, to be verified later in the office.

In conjunction with this data capture through the web application, visits to the District Municipality were undertaken to explain the steps of the project. A brief overview of the existing data was given, together with a short demonstration of the web mapping application, with explanation of the reasons behind this application which is primarily that of onsite data capture while working with the municipal employees.

4.1 Verification of existing information received from the UDM

MMPDNA met with a representative from UDM. The outcomes of this meeting are summarized below.

Date:	12/3/2014	
Officials:	Khomba Mkhize	082 519 6592
	Lungile Cele	082 414 7774
	Sayimite Molo	082 066 3588
	Vuyo Gege	039 688 3487
	Sibonelo Lushaba	082 334 6244
	Sizwe Malinga	082 718 8800
	Thuli Mwelase	039 688 5700

Comments: The Ugu District Municipality provided digital information with regards to the priorities on capital projects for the future.

5. EXISTING WATER SUPPLY SCHEMES

5.1 Water Resources

5.1.1 Rivers

Eight main river systems and numerous minor coastal catchments drain the Ugu region. The major systems with the largest carrying capacity are the Mkomazi, the Mzimkulu and the Mtamvuna which flow all year around. The Mtamvuna River is regarded as being in the best ecological state of all rivers within southern KwaZulu - Natal. The main systems include Mkomazi River, Mpambanyoni River, Mzinto River, Fafa River, Mtwalume River, Mzombe River, Mzimkulu River, Mtamvuna River.

Table 1 indicates the various types of water resources within the UDM. The table indicates the current use of the water source as well as the additional requirements required within a 5 year period.

Water Source	Type	Licensed Abstraction	Current Use	Additional Requirement at Year -5
Umzimkhulu	River	Yes	Raw water supply	Augmentation to increase the capacity
Umtamvuna	River	Yes	Raw water supply	
Umtwalume	River	Yes	Raw water supply	Increase the abstraction point capacity
Harding	Dam	Yes	Raw water supply	Safety inspection and clearing of bushes and trees.
Pungashe	River	Yes	Raw water supply	None
Hlokozi	River	Yes	Raw water supply	None
Vulamehlo	River	Yes	Raw water supply	None
KwaHlongwa	River	Yes	Raw water supply	None
KwaNyuswa	Stream	Yes	Raw water supply	None
KwaFodo	Dam	Yes	Raw water supply	Safety inspection and clearing of bushes and trees.
KwaMbotho	Stream	Yes	Raw water supply	None
Weza	River	Yes	Raw water supply	Augmentation to increase the capacity
E.J.Smith	Dam	Yes	Raw water supply	None
KwaLembe	River	Yes	Raw water supply	None
Ndelu	River	Yes	Raw water supply	None
Assisi	River	Yes	Raw water supply	None

Table 1 – Existing Water Resources

(Source: WSDP 2008)

5.1.2 Dams

The major water bodies in the district are:

- Harding Dam
- KwaFodo Dam
- E.J.Smith Dam
- Nungwane Dam
- Umzinto Dam

5.1.3 Existing Water Schemes

According to reports outlining the reconciliation strategies for the various water schemes in the UDM, the availability of water resources is outlined below.

In undertaking the design of new and additional reticulation for the various local municipalities the available capacities of the various treatment plants were required. With the population growth figures tabled we needed to determine when interventions were required i.e extension of existing water treatment plants or construction of new plant to serve the new/additional demands.

5.1.3.1 **Kwalembe Water Supply Scheme (Vulamehlo LM)**

(Source: First Stage Reconciliation Strategy for Kwalembe Water Supply Scheme Area Vulamehlo Municipality,2011)

Based on the available information from the reconciliation strategy, the current and future water requirements for domestic water use of Kwalembe Water Supply Scheme in UDM which depends on run-of-river abstraction from Mkomazi River can be supplied from the available water supplies without development of additional water supplies.

According to the WSDP, the Mkomazi River catchment is relatively undisturbed with a very low sediment load compared to the other rivers in the UDM. The water quality is considered as moderate to good. The geology and the topography of the area are such that there is no potential for significant groundwater development. Currently there is limited groundwater use in the Kwalembe Water Supply Scheme area. There is no reported water quality problems associated with the groundwater.

The Kwalembe Water Supply Scheme comprises raw water abstraction from the Mkomazi River, a water treatment works near the river and bulk service storage bulk pipelines, and distribution networks. The raw water from Mkomazi River is pumped to the Kwalembe WTW, where it is treated to potable drinking water quality standards. The Kwalembe WTW is the main treatment works that supplies the scheme area.

The total raw water that was expected to be abstracted for treatment at the Kwalembe WTW in 2008 was estimated as 0.6 million m³/a (1.6 ML/d). This includes water services backlogs in the supply area. Based on the estimated raw water requirements, the treated water production with 12% losses was estimated to be 0.5 million m³/a (1.4 ML/d)

The Kwalembe WTW is a conventional treatment plant comprising the following process components:

- (i) *Flocculation channels*: The raw water is pumped from the Mkomazi River to the inlet works where the chemicals are added as the water flows into the flocculation channels at the treatment works, where coagulation after polyelectrolyte dosing takes place to form the flocs.
- (ii) *Clarification (sedimentation) tanks*: The flocs that have formed during the flocculation process are then settled in the sedimentation tanks under gravity. The settled sludge is removed by frequent de-sludging of the tanks and sent to the sludge lagoons where the sludge is dried, while the supernatant water is discharged back into the river. The plant was not designed for recycling of the wastewater.
- (iii) *Rapid Gravity Sand Filtration*: The clarified water is then filtered through a set of rapid gravity sand filters as a final polishing before chlorination of the treated water.
- (iv) *Disinfection*: The filtered water then gravitates to the chlorine contact tanks where chlorination takes place before pumping the potable water to the command reservoirs in Kwalembe supply area for distribution.

The current utilization of the bulk water supply infrastructure is approximately 83%. When compared with the estimated water requirements, the existing bulk water supply infrastructure has sufficient capacity to meet the current water requirements of Kwalembe Water Supply Scheme as well as the future water requirements on a long term sustainable basis. The condition and performance of the treatment works is not known. It is also not known whether the treatment works have been compliant with SANS 241, 2001 for potable drinking water quality standards.

Treatment Work Name	Type of plant	Raw water source	Hydraulic Design capacity (ML/d)	Average flow rate (ML/d)	Treated water production (ML/d)	Current utilisation(% of ave.design capacity)
Kwalembe WTW	Conventional	Mkomazi	2.50	1.67	1.38	83%

Table 2 - Water Treatment Works in operation in the Kwalembe Water Supply Scheme area

(Source: First Stage Reconciliation Strategy for Kwalembe Water Supply Scheme Area Vulamehlo Municipality,2011)

Treated water bulk supply infrastructure

The treated water from the treatment works in the Kwalembe Water Supply Scheme is pumped from the clear water tanks to various service reservoirs in the scheme area before distribution into the scheme's reticulation network (see Table 2). The pumping systems have standby capacity.

Bulk Storage

The total service storage capacity of the Kwalembe Water Supply Scheme area is unknown to determine whether there is sufficient storage to meet the accepted norm of 48 hours of summer peak requirement for urban areas. This norm has been determined to meet the following requirements:

- Balance the fluctuating demands from the distribution system, permitting the source to give a steady or differently phased output;
- Provide a supply during a failure or shutdown of treatment plant, pumps or bulk mains leading to the reservoir; and
- Provide a reserve of water to meet fire and other emergency demands.

Therefore no conclusion could be drawn on whether additional service storage capacity is required currently or in the future. However as the demands grow in the scheme, additional service storage capacity will probably be required sometime in the future to meet the summer peak requirements of Kwalembe Water Supply Scheme.



Figure 8 – Schematic layout of Kwalembe Water Supply Scheme area
 (Source: First Stage Reconciliation Strategy for Kwalembe Water Supply Scheme Area Vulamehlo Municipality,2011)

5.1.3.2 Ndelu Water Supply Scheme (Umzumbe LM)

(Source: First Stage Reconciliation Strategy for Ndelu Water Supply Scheme Area Umzumbe Municipality, 2011)

The main source of supply for Ndelu Water Supply Scheme is the run-of-river abstraction from the Mzumbe River which supplies Ndelu WTW as well as the Kwamalukaka River which supplies KwaHlongwa WTW. Based on the available information from the reconciliation strategy, the supply area of the Ndelu Water Supply Scheme has a water supply deficit as the available water from the Mzumbe River is not sufficient to meet the current water requirements.

The current and future water requirements for domestic water use of Ndelu Water Supply Scheme in Ugu DM which depends on run-of-river abstraction from Mzumbe River cannot be supplied from the available water supplies without development of additional water supplies.

According to the WSDP, the Mzumbe River catchment is relatively undisturbed with a very low sediment load compared to the other rivers in the UDM. The water quality is considered as moderate to good. The geology and the topography of the area are such that there is no potential for significant groundwater development. Currently there is limited groundwater use in the Ndelu Water Supply Scheme area. There is no reported water quality problems associated with the groundwater.

The Ndelu Water Supply Scheme comprises raw water abstraction from the Mzumbe River, a raw water abstraction from Kwamalukaka River, two water treatment works and bulk service storage infrastructure and bulk distribution networks.

Water Treatment Works

Ndelu Water Treatment Works

The total raw water that was expected to be abstracted for treatment at the Ndelu WTW in 2008 was estimated as 1.5 million m³/a (4.1 ML/d). This includes water services backlogs in the supply area. Based on the estimated raw water requirements, the treated water production with 12% losses was estimated to be 1.3 million m³/a (3.6 ML/d).

The Ndelu WTW is a conventional treatment plant comprising the following process components:

- (i) *Flocculation channels*: The raw water is pumped from the Mzumbe River to the inlet works where the chemicals are added as the water flows into the flocculation channels where coagulation, after polyelectrolyte dosing, takes place to form the flocs.
- (ii) *Clarification (sedimentation) tanks*: The flocs that have formed during the flocculation process are then settled in the sedimentation tanks under gravity. The settled sludge is removed by frequent de-sludging of the tanks and sent to the sludge lagoons where the sludge is dried while the supernatant water is discharged back into the river. The plant was not designed for recycling of the wastewater.

- (iii) *Rapid Gravity Sand Filtration*: The clarified water is then filtered through a set of rapid gravity sand filters as a final polishing before chlorination of the treated water.
- (iv) *Disinfection*: The filtered water then gravitates to the chlorine contact tanks where chlorination takes place before pumping the potable water to the command reservoirs in Ndelu supply area for distribution.

KwaHlongwa Water Treatment Works

The raw water from Kwamalukaka River is pumped to the KwaHlongwa WTW where it is treated to potable drinking water quality standards. The KwaHlongwa WTW is the other treatment works that supplies the scheme area. The peak hydraulic design capacity of the water treatment works is 1.1 ML/d or 0.4 million m³/a (WSDP, 2008). The average annual flow rate of the treatment works is estimated to be 0.75 ML/d or 0.3 million m³/a based on a peaking factor of 1.5.

The KwaHlongwa WTW is a conventional treatment plant comprising the following process components:

- (v) *Flocculation channels*: The raw water is pumped from the Kwamalukaka River to the inlet works where the chemicals are added as the water flows into the flocculation channels where coagulation, after polyelectrolyte dosing, takes place to form the flocs.
- (vi) *Clarification (sedimentation) tanks*: The flocs that have formed during the flocculation process are then settled in the sedimentation tanks under gravity. The settled sludge is removed by frequent de-sludging of the tanks and sent to the sludge lagoons where the sludge is dried while the supernatant water is discharged back into the river. The plant was not designed for recycling of the wastewater.
- (vii) *Rapid Gravity Sand Filtration*: The clarified water is then filtered through a set of rapid gravity sand filters as a final polishing before chlorination of the treated water.
- (viii) *Disinfection*: The filtered water then gravitates to the chlorine contact tanks where chlorination takes place before pumping the potable water to the command reservoirs in the southern area of Ndelu water supply scheme for distribution.

The current utilization of the bulk water supply infrastructure is approximately 102%. When compared with the estimated water requirements, the existing bulk water supply infrastructure does not have sufficient capacity to meet the current water requirements of Ndelu Water Supply Scheme as well as the future water requirements on a long term sustainable basis.

The condition and performance of the two treatment works is not known. It is also not known whether the treatment works have generally been compliant with SANS 241, 2001 for potable drinking water quality standards.

Treatment Work Name	Type of plant	Raw water source	Hydraulic Design capacity (ML/d)	Average flow rate (ML/d)	Treated water production (ML/d)	Current utilisation (% of ave.design capacity)
Ndelu WTW	Conventional	Umzumbe	2.10	1.40	1.40	100%
KwaHlongwa WTW	Conventional	Kwamalukaka	1.13	0.75	0.80	107%
Total			3.23	2.15	2.20	102.3%

Table 3 - Water Treatment Works in operation in the Ndelu Water Supply Scheme area
(Source: First Stage Reconciliation Strategy for Ndelu Water Supply Scheme Area Umzumbe Municipality,2011)

Treated water bulk supply infrastructure

The treated water from the two treatment works in the Ndelu Water Supply Scheme is pumped from the clearwater tanks to various service reservoirs in the scheme area before distribution into the scheme's reticulation network (see table above). The pumping systems have standby capacity.

Bulk Storage

The total service storage capacity of the Ndelu Water Supply Scheme area is unknown to enable determination of whether there is sufficient storage to the accepted norm of 48 hours of summer peak requirement for urban areas. This norm has been determined to meet the following requirements:

- Balance the fluctuating demands from the distribution system, permitting the source to give a steady or differently phased output;
- Provide a supply during a failure or shutdown of treatment plant, pumps or bulk mains leading to the reservoir; and
- Provide a reserve of water to meet fire and other emergency demands.

Therefore no conclusion could be drawn on whether additional service storage capacity is required currently or in the future. However as the demands grow in the scheme, additional service storage capacity will be required sometime in the future to meet the future summer peak requirements of Ndelu Water Supply Scheme.




Figure 9 – Schematic layout of Ndelu Water Supply Scheme area

(Source: First Stage Reconciliation Strategy for Ndelu Water Supply Scheme Area Umzumbe Municipality, 2011)

5.1.3.3 Pungase Water Supply Scheme (Umzumbe LM)

(Source: First Stage Reconciliation Strategy for Pungase Water Supply Scheme Area Umzumbe Municipality, 2011)

Based on the available information from the reconciliation strategy, the supply area of the Pungashe Water Supply Scheme has a water supply deficit as the available water from the Mhlabatshane River is not sufficient to meet the current water requirements. The current and future water requirements for domestic water use of Pungashe Water Supply Scheme in UDM which depends on run-of-river abstraction from Mhlabatshane River cannot be supplied from the available water supplies without development of additional water supplies. This depends on the operating rules of the two sources of supply, namely the Mhlabatshane and Umzumbe Rivers.

According to the WSDP, the Mhlabatshane River catchment is relatively undisturbed with a very low sediment load compared to the other rivers in the UDM. The water quality is considered as moderate to good.

The geology and the topography of the area are such that there is no potential for significant groundwater development. Currently there is limited groundwater use in the Pungashe Water Supply Scheme area. There is no reported water quality problems associated with the groundwater.

Pungashe Water Treatment Works

The raw water from Mhlabatshane River is pumped to the Pungashe WTW where it is treated to potable drinking water quality standards. The Pungashe WTW is the main treatment works that supplies the scheme area. The peak hydraulic design capacity of the water treatment works is only 0.45 ML/d or 0.2 million m³/a (WSDP, 2008). The average annual flow rate of the treatment works is estimated to be 0.3 ML/d or 0.1 million m³/a based on a peaking factor of 1.5.

The table below provides the future raw water requirements for the different growth scenarios at the current estimated water use efficiency levels. The future raw water requirements allow for the high system losses of 24% of raw water abstracted based on an estimate of present (2008) raw water abstraction in order to supply the water required at present at the point of consumption. In order to supply the water required, the additional raw water abstracted in 2008 amounted to approximately 0.4 million m³/a (1.2 ML/d) to deliver the water requirements at the consumer end.

The Pungashe WTW is a conventional treatment plant comprising the following process components:

- (i) *Flocculation channels*: The raw water is pumped from the Mhlabatshane River to the inlet works where the chemicals are added as the water flows into the flocculation channels, where coagulation after polyelectrolyte dosing, takes place to form the flocs.
- (ii) *Clarification (sedimentation) tanks*: The flocs that have formed during the flocculation process are then settled in the sedimentation tanks under gravity. The settled sludge is removed by frequent de-sludging of the tanks and sent to the sludge lagoons where the sludge is dried, while the supernatant water is discharged back into the river. The plant was not designed for recycling of the wastewater.

- (iii) *Rapid Gravity Sand Filtration*: The clarified water is then filtered through a set of rapid gravity sand filters as a final polishing before chlorination of the treated water.
- (iv) *Disinfection*: The filtered water then gravitates to the chlorine contact tanks where chlorination takes place before pumping the potable water to the command reservoirs in the Pungashe supply area for distribution.

The current utilization of the bulk water supply infrastructure is approximately 100%. When compared with the estimated water requirements, the existing bulk water supply infrastructure does not have sufficient capacity to meet the current water requirements of Pungashe Water Supply Scheme as well as the future water requirements on a long term sustainable basis.

The condition and performance of the treatment works is not known. It is also not known whether the treatment works have been generally compliant with SANS 241, 2001 for potable drinking water quality standards.

Treatment Work Name	Type of plant	Raw water source	Hydraulic Design capacity (ML/d)	Average flow rate (ML/d)	Treated water production (ML/d)	Current utilisation (% of ave.design capacity)
Pungashe WTW	Conventional	Mhlabatshane	0.45	0.3	0.3	100%

Table 4 - Water Treatment Works in operation in the Pungase Water Supply Scheme area

(Source: First Stage Reconciliation Strategy for Pungase Water Supply Scheme Area Umzumbe Municipality,2011)

Treated water bulk supply infrastructure

The treated water from the two treatment works in the Pungashe Water Supply Scheme is pumped from the clear water tanks to various service reservoirs in the scheme area before distribution into the scheme's reticulation network (see table above). The pumping systems have standby capacity.

Bulk Storage

The total service storage capacity of the Pungashe Water Supply Scheme area is unknown so it cannot be determined if there is sufficient storage to meet the accepted norm of 48 hours of summer peak requirement for urban areas. This norm has been determined to meet the following requirements:

- Balance the fluctuating demands from the distribution system, permitting the source to give a steady or differently phased output;
- Provide a supply during a failure or shutdown of treatment plant, pumps or bulk mains leading to the reservoir; and
- Provide a reserve of water to meet fire and other emergency demands.

Therefore no conclusion could be drawn on whether additional service storage capacity is required currently or in the future. However as the demands grow in the scheme, additional service storage capacity will be required to meet the future summer peak requirements of Pungashe Water Supply Scheme.



Figure 10 – Schematic layout of Pungashe Water Supply Scheme area
 (Source: First Stage Reconciliation Strategy for Pungashe Water Supply Scheme Area Umzumbe Municipality, 2011)

5.1.3.4 Umtamvuna Water Supply Scheme (Hibiscus Coast LM)

(Source: First Stage Reconciliation Strategy for Umtamvuna Water Supply Scheme Area Hibiscus Coast Municipality)

The main source of supply for Umtamvuna Water Supply Scheme is the run-of-river abstraction from the Mtamvuna River. Based on the available information from the reconciliation strategy, the Mtamvuna Catchment has a water supply surplus. The current and future water requirements for domestic water use of Umtamvuna Water Supply Scheme in UDM which depends on run-of-river abstraction from Mtamvuna River can be supplied from the available water supplies without development of additional water supplies.

According to the WSDP, there are no known major water quality problems in the Umtamvuna Water Supply Scheme area. It is however likely that the quality of the Mtamvuna River is, however, significantly affected during periods of rainfall due to the land use activities upstream and soil erosion as the turbidity levels are very high during rainfall periods. The geology and the topography of the area are such that there is no potential for significant groundwater development.

Currently there is no groundwater use in the Umtamvuna Water Supply Scheme area. There is no reported water quality problems associated with the groundwater.

The Umtamvuna Water Supply Scheme comprises raw water abstraction from the Mtamvuna River in quaternary catchment T40E, a balancing dam near the river, a water treatment works and bulk service storage infrastructure and bulk distribution networks.

Water Treatment Works

The raw water is pumped to the Umtamvuna WTW where it is treated to potable drinking water quality standards. The Umtamvuna WTW is the only treatment works that supplies the scheme area. The peak hydraulic design capacity of the water treatment works is only 20 ML/d or 7.3 million m³/a (WSDP, 2008). The average annual flow rate of the treatment works is estimated to be 13.3 ML/d or 4.9 million m³/a based on a peaking factor of 1.5.

The Umtamvuna WTW is a conventional treatment plant comprising the following process components:

- (i) *Flocculation channels*: The raw water is pumped from the Mtamvuna River to the inlet works where the chemicals are added as the water flows into the flocculation channels at the treatment works. Coagulation results from polyelectrolyte dosing to form the flocs.
- (ii) *Clarification (sedimentation) tanks*: The flocs that have formed during the flocculation process are then settled in the sedimentation tanks under gravity. The settled sludge is removed by frequent de-sludging of the tanks and sent to the sludge lagoons where the sludge is dried while the supernatant water is discharged back into the river. The plant was not designed for recycling of the wastewater.

- (iii) *Rapid Gravity Sand Filtration*: The clarified water is then filtered through a set of rapid gravity sand filters as a final polishing before chlorination of the treated water.
- (iv) *Disinfection*: The filtered water then gravitates to the chlorine contact tanks where chlorination takes place before pumping the potable water to the command reservoirs from where the treated water is distributed inland and to the coastal areas respectively.

The current utilization of the bulk water supply infrastructure is approximately 101%. The existing bulk water supply infrastructure has sufficient capacity to meet the current water requirements of Umtamvuna Water Supply Scheme but does not have sufficient capacity to meet future water requirements on a long term sustainable basis.

Treatment Work Name	Type of plant	Raw water source	Hydraulic Design capacity (ML/d)	Average flow rate (ML/d)	Treated water production (ML/d)	Current utilisation (% of ave.design capacity)
Umtamvuna	Conventional	Mtamvuna	20.00	13.33	13.43	101%

Table 5 - Water Treatment Works in operation in the Umtamvuna Water Supply Scheme area
(Source: First Stage Reconciliation Strategy for Umtamvuna Water Supply Scheme Area Hibiscus Coast Municipality)

According to the Blue Drop Report, 2009, the performance of the Umtamvuna Water Supply Scheme was classified as very good with the scheme likely to attain blue drop status in 2011. The condition of the components making up the scheme was in a generally good.

The performance of the works has been very good even during rainfall seasons when there are changes to the quality of the raw water with high turbidity levels due to lack of pre-settlement. The treatment works therefore has generally been compliant with SANS 241, 2001 for potable drinking water quality standards.

Treated water bulk supply infrastructure

The treated water from the treatment works in the Umtamvuna Water Supply Scheme is pumped from the clearwater tanks to various service reservoirs in the scheme area before distribution into the scheme's reticulation network. The pumping systems have standby capacity.

Bulk Storage

The total service storage capacity of the Umtamvuna Water Supply Scheme area is unknown to determine whether there is sufficient storage to meet the accepted norm of 48 hours of summer peak requirement for urban areas. This norm has been determined to meet the following requirements:

- Balance the fluctuating demands from the distribution system, permitting the source to give a steady or differently phased output;

- Provide a supply during a failure or shutdown of treatment plant, pumps or bulk mains leading to the reservoir; and
- Provide a reserve of water to meet fire and other emergency demands.

Therefore no conclusion could be drawn on whether additional service storage capacity is required currently or in the future. However as the demands grow in the scheme, additional service storage capacity will be required to meet the future summer peak requirements of Umtamvuna Water Supply Scheme.




Figure 11 – Schematic layout of Umtamvuna Water Supply Scheme area
 (Source: First Stage Reconciliation Strategy for Umtamvuna Water Supply Scheme Area Hibiscus Coast Municipality)

5.1.3.5 Mtwalume Water Supply Scheme (Umzumbe LM)

(Source: First Stage Reconciliation Strategy for Mtwalume Water Supply Scheme Area Umzumbe Municipality)

The main source of supply for Mtwalume Water Supply Scheme is the well points in the Mtwalume River. Based on the available information from the reconciliation strategy; the Mtwalume Catchment does not have sufficient water available. The current and future water requirements for domestic water use of Mtwalume Water Supply Scheme in UDM which depends on abstractions from the Mtwalume River cannot be supplied from the available water supplies without development of additional water supplies or supplementing the water supplies from other sources. There is not sufficient runoff during low flow periods to meet the long term future water requirements of the scheme as the dam storage capacity is very limited.

According to the WSDP, there are no major water quality problems in the Mtwalume Water Supply Scheme area. The quality of the Mtwalume system was considered satisfactory. The geology and the topography of the area are such that there is no potential for significant groundwater development. Currently there is no groundwater use in the Mtwalume Water Supply Scheme area. There is no reported water quality problems associated with the groundwater.

Water Treatment Works

Raw water is pumped from the wells in Mtwalume River to the Mtwalume WTW where it is treated to potable drinking water quality standards. The Mtwalume WTW is the only treatment works that supplies the scheme area. This is supplemented with a number of boreholes supplying the outlying rural communities in the supply area.

The peak hydraulic design capacity of the water treatment works is only 9.0 ML/d or 3.3 million m³/a (WSDP, 2008). The average annual flow rate of the treatment works is estimated to be 6.0 ML/d or 2.2 million m³/a based on a peaking factor of 1.5.

The Mtwalume WTW is a conventional treatment plant comprising the following process components:

- (i) *Balancing tank*: The raw water is pumped from the Mtwalume River into a balancing tank which provides sufficient contact time for natural settling of the suspended solids to take place in the tanks as well as providing the balancing storage for the plant. The supernatant water is then mixed with the chemicals such as polyelectrolytes to form the flocs during flocculation in the outlet channels to the sedimentation tanks.
- (ii) *Clarification (sedimentation) tanks*: The flocs that have formed during the flocculation process are then settled in the sedimentation tanks through an upflow sedimentation process. The settled sludge is removed by frequent de-sludging of the tanks and sent to the sludge lagoons where the sludge is dried while the supernatant water is discharged back into the river. The plant was not designed for recycling of the wastewater.
- (iii) *Rapid Gravity Sand Filtration*: The clarified water is then filtered through a set of rapid gravity sand filters as a final polishing before chlorination of the treated water.

- (iv) *Disinfection*: The filtered water then gravitates to the chlorine contact tanks where chlorination takes place before pumping the potable water to the command reservoirs in Mtwalume as well as Mnamfu for distribution to the rest of the scheme area.

Borehole supply

The Mtwalume Water Supply Scheme is also supplied from groundwater for the outlying areas of the scheme which have not been linked to the existing bulk water supply scheme. This is mainly inland where the rural villages of Goloqolo are supplied from boreholes. The total capacity of the groundwater into Mtwalume supply area was estimated to be 1.44 ML/d or 0.5 million m³/a.

The current utilisation of the Mtwalume WTW is approximately 104%. The existing bulk water supply infrastructure therefore has only sufficient capacity to meet the current water requirements of Mtwalume Water Supply Scheme, excluding any current water services backlogs included in the water requirements estimates. However, as the future water requirements increase as the backlogs are removed, the existing bulk water supply infrastructure cannot meet these demands on a long term sustainable basis under the current water use estimates and practices.

Treatment Work Name	Type of plant	Raw water source	Hydraulic Design capacity (ML/d)	Average flow rate (ML/d)	Treated water production (ML/d)	Current utilisation(% of average design capacity)
Umtwalume WTW	Conventional	Mtwalume	4.50	3.00	3.16	105%
Mtuwalume WTW upgrade	N/A	Mtwalume	4.50	3.00	3.16	105%
Boreholes			1.44	1.44	1.44	100%
Total			10.44	7.44	7.76	104.3%

Table 6 - Water Treatment Works in operation in the Mtwalume Water Supply Scheme area

(Source: First Stage Reconciliation Strategy for Mtwalume Water Supply Scheme Area Umzumbe Municipality)

According to the Blue Drop Report, 2009, the performance of the Mtwalume Water Supply Scheme was classified as very good with the scheme likely to attain blue drop status in 2011. The condition of the components making up the scheme was generally good.

The treatment works therefore has generally been compliant with SANS 241, 2001 for potable drinking water quality standards.

Treated water bulk supply infrastructure

The treated water from the treatment works in the Mtwalume Water Supply Scheme is pumped from the clearwater tanks to various service reservoirs in the scheme area before distribution into the scheme's reticulation network (see table above). The pumping systems have standby capacity.

Bulk Storage

The total service storage capacity of the Mtwalume Water Supply Scheme area is unknown to determine whether there is sufficient storage to the accepted norm of 48 hours of summer peak requirement for urban areas. This norm has been determined to meet the following requirements:

- Balance the fluctuating demands from the distribution system, permitting the source to give a steady or differently phased output;
- Provide a supply during a failure or shutdown of treatment plant, pumps or bulk mains leading to the reservoir; and
- Provide a reserve of water to meet fire and other emergency demands.

Therefore no conclusion could be drawn on whether additional service storage capacity is required currently or in the future. However as the demands grow in the scheme, additional service storage capacity will be required sometime in the future to meet the summer peak requirements of Mtwalume Water Supply Scheme.




Figure 12 – Schematic layout of Mtwalume Water Supply Scheme area
 (Source: First Stage Reconciliation Strategy for Mtwalume Water Supply Scheme Area Umzumbe Municipality)

5.1.3.6 Umzimkhulu Water Supply Scheme (Hibiscus Coast LM)

(Source: First Stage Reconciliation Strategy for Umzimkhulu Water Supply Scheme Area Hibiscus Coast Municipality)

The main source of supply for Lower Mzimkhulu Water Supply Scheme area is the run-of-river abstraction from the Mzimkhulu River, below the confluence with the Mzimkhulwana River. There is not sufficient unregulated runoff from the Mzimkulu River catchment during low flow periods to meet the current and future water requirements of the Umzimkhulu Water Supply Scheme area as well as those of the other water users in the catchment at adequate assurances of supply. Therefore the water supplies available to the Lower Mzimkulu Water Supply Scheme area from the Mzimkhulu River catchment must be augmented immediately.

According to the WSDP, there are no known major water quality problems in the Lower Mzimkhulu Water Supply Scheme area. It is however likely that the quality of the Mzimkhulu River is significantly affected during periods of rainfall, due to the land use activities upstream, particularly in the rural areas, resulting in soil erosion. This results in the high turbidity levels during rainfall periods.

The geology and the topography of the area are such that there is no potential for significant groundwater development. Currently there is no groundwater use in the Lower Mzimkhulu Water Supply Scheme area. There is no reported water quality problems associated with the groundwater.

Water Treatment Works

The Lower Mzimkhulu Water Supply Scheme comprises a raw water abstraction works, water treatment works, at Boboyi, and bulk service storage infrastructure and bulk distribution networks. The raw water is pumped to the Boboyi WTW where it is treated to potable drinking water quality standards. The Boboyi WTW is the only treatment works that supplies the scheme area. The peak hydraulic design capacity of the water treatment works is only 54 ML/d or 19.7 million m³/a (WSDP, 2008). The average annual flow rate of the treatment works is estimated to be 36.0 ML/d or 13.1 million m³/a based on a peaking factor of 1.5. The Boboyi WTW is a conventional treatment plant, comprising the following process components:

- (i) Flocculation channels: The raw water is pumped from the Mzimkhulu River to the inlet works, where the chemicals are added as the water flows into the flocculation channels. Polyelectrolyte dosing takes place resulting in coagulation and forms the flocs.
- (ii) Clarification (sedimentation) tanks: The flocs that have formed during the flocculation process are then settled in the sedimentation tanks under gravity. The settled sludge is removed by frequent de-sludging of the tanks and sent to the sludge lagoons, where the sludge is dried. The supernatant water is discharged back into the river. The plant was not designed for recycling of the wastewater.
- (iii) Rapid Gravity Sand Filtration: The clarified water is then filtered through a set of rapid gravity sand filters as a final polishing, before chlorination of the treated water.

- (iv) Disinfection: The filtered water then gravitates to the chlorine contact tanks where chlorination takes place, before pumping the potable water to the command reservoirs in the Lower Mzimkhulu Water Supply Scheme area for distribution.

As illustrated in Table 7, the current utilization of the bulk water supply infrastructure is approximately 117%. The existing bulk water supply infrastructure does not have sufficient capacity to meet the current water requirements of the Lower Mzimkhulu Water Supply Scheme, as well as the future water requirements on a long term sustainable basis.

Treatment Work Name	Type of plant	Raw water source	Hydraulic Design capacity (ML/d)	Average flow rate (ML/d)	Treated water production (ML/d)	Current utilisation (% of ave.design capacity)
Bobhoyi	Conventional	Mzimkhulu River	54.00	36.00	42.06	117%

Table 7 - Water Treatment Works in operation in the Umzimkhulu Water Supply Scheme area
(Source: First Stage Reconciliation Strategy for Umzimkhulu Water Supply Scheme Area Hibiscus Coast Municipality)

According to the Blue Drop Report, 2009, the performance of the Umzimkhulu Water Supply Scheme was classified as very good with the scheme likely to attain blue drop status in 2011. The condition of the components making up the scheme was in a generally good. The performance of the works has been very good, even during rainfall seasons when there are changes to the quality of the raw water with high turbidity levels, due to lack of pre-settlement. The treatment works therefore has generally been compliant with SANS 241, 2001 for potable drinking water quality standards.

Treated water bulk supply infrastructure

The treated water from the treatment works is pumped from the clear water tanks to various service reservoirs in the scheme area before distribution into the scheme's reticulation network. The pumping systems have standby capacity.

Bulk Storage

The total service storage capacity of the Lower Mzimkhulu Water Supply Scheme area is not known to enable a determination of whether there is sufficient storage to the accepted norm of 48 hours of summer peak requirement for urban areas. This norm has been determined to meet the following requirements:

- Balance the fluctuating demands from the distribution system, permitting the source to give a steady or differently phased output;
- Provide a supply during a failure or shutdown of the treatment plant, pumps or bulk mains leading to the reservoir; and
- Provide a reserve of water to meet fire and other emergency demands.

Therefore no conclusion could be drawn on whether additional service storage capacity is required currently or in the future. However, as the demands grow in the scheme, additional service storage capacity will be required sometime in the future, to meet the future summer peak requirements of Lower Mzimkhulu Water Supply Scheme.




Figure 13 – Schematic layout of Lower Umzimkhulu Water Supply Scheme area
 (Source: First Stage Reconciliation Strategy for Umzimkhulu Water Supply Scheme Area Hibiscus Coast Municipality)

5.1.3.7 Umzinto Water Supply Scheme (Umdoni LM)

(Source: First Stage Reconciliation Strategy for Umzinto Water Supply Scheme Area Umdoni Municipality)

The main source of supply for Umzinto Water Supply Scheme is the Esperanza weir in the Umzinto River as well as from EJ Smith Dam in the Mzimayi River. Furthermore the Umgeni Water is implementing the South Coast Pipeline Phase 2 (SCP-2a) to supplement the water supplies of the Umzinto Water Supply Scheme from the Umgeni System in the Ethekwini Metropolitan Municipality. The Mzimayi and Umzinto River are regulated with the EJ Smith Dam and Esperanza weir being the main storages in the system with most users relying on run-of-river abstraction.

The water requirements in the Region are estimated to be 18 million m³/a. The Middle South Coast Region therefore has a water supply deficit of 4 million m³/a. The water supply shortages are experienced in the dry periods because there is not sufficient storage capacity to meet demands during the low flow periods. Based on the available information from the reconciliation strategy, the Umzinto Catchment has a water supply deficit. The current and future water requirements for domestic water use of Umzinto Water Supply Scheme in UDM which depends on abstractions from the Umzinto River and Mzimayi cannot be supplied from the available water supplies without development of additional water supplies or supplementing the water supplies from other sources. There is not sufficient runoff during low flow periods to meet the long term future water requirements of the scheme as the dam storage capacity is very limited.

According to the Umgeni Water Master Plan, there are major water quality problems in the Umzinto Water Supply Scheme area. The quality of the Mzimayi system was considered not satisfactory due to ongoing sewer problems, while the EJ Smith Dam has been highly impacted by the town, farming and industrial activities in the area. The geology and the topography of the area are such that there is no potential for significant groundwater development. Currently there is no groundwater use in the Umzinto Water Supply Scheme area. There is no reported water quality problems associated with the groundwater.

Water Treatment Works

The raw water is pumped to the Umzinto WTW where it is treated to potable drinking water quality standards. The Umzinto WTW is the only treatment works that supplies the scheme area. The peak hydraulic design capacity of the water treatment works is only 13.6 ML/d or 5.0 million m³/a (WSDP, 2008). The average annual flow rate of the treatment works is estimated to be 9.1 ML/d or 3.3 million m³/a based on a peaking factor of 1.5.

The Umzinto WTW is a conventional treatment plant comprising the following process components:

- (i) *Flocculation channels*: The raw water is pumped from the Umzinto River and Esperanza to the inlet works where the chemicals are added as the water flows into the flocculation channels at the treatment works. Polyelectrolyte dosing takes place resulting in coagulation to form the flocs.
- (ii) *Clarification (sedimentation) tanks*: The flocs that have formed during the flocculation process are then settled in the sedimentation tanks under gravity. The settled sludge is

removed by frequent de-sludging of the tanks and sent to the sludge lagoons where the sludge is dried while the supernatant water is discharged back into the river. The plant was not designed for recycling of the wastewater.

- (iii) *Rapid Gravity Sand Filtration*: The clarified water is then filtered through a set of rapid gravity sand filters as a final polishing before chlorination of the treated water.
- (iv) *Disinfection*: The filtered water then gravitates to the chlorine contact tanks where chlorination takes place before pumping the potable water to the command reservoirs in Umzinto scheme area for distribution.

South Coast Pipeline

The Umzinto Water Supply Scheme is also supplied with treated water from the Umgeni Water's South Coast Pipeline (SCP). The total capacity of the SCP into the Umzinto supply area at Scottburgh South Reservoir after the commissioning of the phase 2(a) is envisaged to be 17.5 ML/d or 6.4 million m³/a (Umgeni Water, 2010)

As illustrated in Table 8, the current utilisation of the Umzinto WTW is 77% because of limited raw water supplies while the SCP has a current utilisation of 13% of the capacity of the bulk pipeline. The existing bulk water supply infrastructure therefore has sufficient capacity to meet the current water requirements of Umzinto Water Supply Scheme as well as the future water requirements on a long term sustainable basis. This is assuming there is a sufficient raw water supply in the Umgeni System to deliver the capacity of the SCP.

Treatment Work Name	Type of plant	Raw water source	Hydraulic Design capacity (ML/d)	Average flow rate (ML/d)	Treated water production (ML/d)	Current utilisation (% of avedesign capacity)
Umzinto WTW Capacity	Conventional	Umzinto, Mzimayi	13.60	9.07	7.00	77%
South Coast Pipeline	N/A	Umgeni Water	-	17.50	2.21	13%
Total			13.60	26.57	9.21	34.7%

Table 8 - Water Treatment Works in operation in the Umzinto Water Supply Scheme area

(Source: First Stage Reconciliation Strategy for Umzinto Water Supply Scheme Area Umdoni Municipality)

According to the Blue Drop Report, 2009, the performance of the Umzinto Water Supply Scheme was classified as very good with the scheme likely to attain blue drop status in 2011. The condition of the components making up the scheme was generally good.

The treatment works therefore has generally been compliant with SANS 241, 2001 for potable drinking water quality standards.

Treated water bulk supply infrastructure

The treated water from the treatment works in the Umzinto Water Supply Scheme is pumped from the clearwater tanks to various service reservoirs in the scheme area before distribution into the scheme's reticulation network (see table above). The pumping systems have standby capacity.

Bulk Storage

The total service storage capacity of the Umzinto Water Supply Scheme area is unknown. Therefore one cannot determine whether there is sufficient storage to the accepted norm of 48 hours of summer peak requirement for urban areas. This norm has been determined to meet the following requirements:

- Balance the fluctuating demands from the distribution system, permitting the source to give a steady or differently phased output;
- Provide a supply during a failure or shutdown of treatment plant, pumps or bulk mains leading to the reservoir; and
- Provide a reserve of water to meet fire and other emergency demands.

Therefore no conclusion could be drawn on whether additional service storage capacity is required currently or in the future. However as the demands grow in the scheme, additional service storage capacity will be required sometime in the future to meet the future summer peak requirements of Umzinto Water Supply Scheme.




Figure 14 – Schematic layout of Umzinto Water Supply Scheme area
 (Source: First Stage Reconciliation Strategy for Umzinto Water Supply Scheme Area Umdoni Municipality)

5.1.3.8 Vulamehlo Water Supply Scheme (Vulamehlo LM)

(Source: First Stage Reconciliation Strategy for Vulamehlo Water Supply Scheme Area Vulamehlo Municipality)

The main source of supply for the Vulamehlo Water Supply Scheme is the run-of-river abstraction from the Mtwalume River, whilst a dam on the Mzinto River supplies the Braemar WTW. According to the ISP, the available water in the South Coast catchments which make up the Mtwalume, Mzinto, and Mpambanyoni River catchments is in deficit. Based on the available information from the reconciliation strategy, the supply area of the Vulamehlo Water Supply Scheme has a water supply deficit, as the available water from the two sources is not sufficient to meet the current water requirements.

The current and future water requirements for domestic water use of the Vulamehlo Water Supply Scheme in the UDM which depends on run-of-river abstraction from Mtwalume River and the Mzinto River cannot be supplied from the available water supplies, without development of additional water supplies. This depends on the operating rules of the two sources of supply.

According to the WSDP, the conductivity of the water in the Mzinto River has been increasing substantially while the water quality in the Mtwalume River is considered of average quality with slight increases in the chloride levels and alkalinity concentration. The geology and the topography of the area are such that there is no potential for significant groundwater development. Currently there is limited groundwater use in the Vulamehlo Water Supply Scheme area. There is no reported water quality problems associated with the groundwater.

The Vulamehlo Water Supply Scheme comprises raw water abstraction from the Mtwalume River which supplies Vulamehlo WTW as well as from the Mzinto River which supplies Braemar WTW, two water treatment works near Jolivet and Braemar respectively and bulk service storage infrastructure and bulk distribution networks.

Water Treatment Works

Vulamehlo (Jolivet) Water Treatment Works

The raw water from Mtwalume River is pumped to the Vulamehlo WTW, where it is treated to potable drinking water quality standards. The Vulamehlo WTW is the main treatment works that supplies the scheme area. The peak hydraulic design capacity of the water treatment works is only 2.25 ML/d or 0.82 million m³/a (WSDP, 2008). The average annual flow rate of the treatment works is estimated to be 1.5 ML/d or 0.6 million m³/a based on a peaking factor of 1.5.

The Vulamehlo WTW is a conventional treatment plant comprising the following process components:

- (i) *Flocculation channels*: The raw water is pumped from the Mtwalume River to the inlet works where the chemicals are added as the water flows into the flocculation channels at the treatment works where coagulation after polyelectrolyte dosing takes place to form the flocs.

- (ii) *Clarification (sedimentation) tanks:* The flocs that have formed during the flocculation process are then settled in the sedimentation tanks under gravity. The settled sludge is removed by frequent de-sludging of the tanks and sent to the sludge lagoons where the sludge is dried while the supernatant water is discharged back into the river. The plant was not designed for recycling of the wastewater.
- (iii) *Rapid Gravity Sand Filtration:* The clarified water is then filtered through a set of rapid gravity sand filters as a final polishing before chlorination of the treated water.
- (iv) *Disinfection:* The filtered water then gravitates to the chlorine contact tanks where chlorination takes place before pumping the potable water to the command reservoirs in Vulamehlo supply area for distribution.

Braemar Water Treatment Works

The raw water from Mzinto Dam is pumped to the Braemar WTW where it is treated to potable drinking water quality standards. The Braemar WTW is the secondary treatment works that supplies the scheme area. The peak hydraulic design capacity of the water treatment works is only 1.5 ML/d or 0.6 million m³/a (WSDP, 2008). The average annual flow rate of the treatment works is estimated to be 1.0 ML/d or 0.4 million m³/a based on a peaking factor of 1.5.

The Braemar WTW is a conventional treatment plant, comprising the same process components as the Vulamehlo WTW.

Potable water is pumped to the command reservoirs in Braemar town area for distribution. The current utilisation of the bulk water supply infrastructure is approximately 125%. When compared with the estimated water requirements, the existing bulk water supply infrastructure does not have sufficient capacity to meet the current water requirements of Vulamehlo Water Supply Scheme as well as the future water requirements on a long term sustainable basis.

Treatment Work Name	Type of plant	Raw water source	Hydraulic Design capacity (ML/d)	Average flow rate (ML/d)	Treated water production (ML/d)	Current utilisation (% of ave.design capacity)
Vulamehlo (Jolivet) WTW Capacity	Conventional	Mtwalume River	2.25	1.50	1.95	130%
Braemar WTW Capacity	Conventional	Mzinto River Dam	1.50	1.00	1.35	135%
Boreholes			0.72	0.72	0.72	100%
Total			4.47	3.22	4.02	124.8%

Table 9 - Water Treatment Works in operation in the Vulamehlo Water Supply Scheme area

(Source: First Stage Reconciliation Strategy for Vulamehlo Water Supply Scheme Area Vulamehlo Municipality)

The condition and performance of the two treatment works is not known. It is also not known whether the treatment works have been generally compliant with SANS 241, 2001 for potable drinking water quality standards.

Treated water bulk supply infrastructure

The treated water from the two treatment works in the Vulamehlo Water Supply Scheme is pumped from the clearwater tanks to various service reservoirs in the scheme area before distribution into the scheme's reticulation network. The pumping systems have standby capacity.

Bulk Storage

The total service storage capacity of the Vulamehlo Water Supply Scheme area is unknown. It is thus not possible to determine whether there is sufficient storage to the accepted norm of 48 hours of summer peak requirement for urban areas. This norm has been determined to meet the following requirements:

- Balance the fluctuating demands from the distribution system, permitting the source to give a steady or differently phased output;
- Provide a supply during a failure or shutdown of treatment plant, pumps or bulk mains leading to the reservoir; and
- Provide a reserve of water to meet fire and other emergency demands.

Therefore no conclusion could be drawn on whether additional service storage capacity is required currently or in the future. However, as the demands grow in the scheme, additional service storage capacity will be required sometime in the future, to meet the future summer peak requirements of Vulamehlo Water Supply Scheme.




Figure 15 – Schematic layout of Vulamehlo Water Supply Scheme area
 (Source: First Stage Reconciliation Strategy for Vulamehlo Water Supply Scheme Area Vulamehlo Municipality)

5.1.3.9 Weza Harding Water Supply Scheme (Umuziwabantu LM)

(Source: First Stage Reconciliation Strategy for Weza Water Supply Scheme Area Umuziwabantu Municipality)

The main source of supply for Weza Harding Water Supply Scheme is the run-of-river abstraction from the Weza River and the municipal dam in a tributary of the Mzimkulwana River which supplies Harding WTW. The Weza and Mzimkhulwana Rivers is not well regulated with the water users relying on run-of-river abstraction. According to the ISP, the available water in the Mtamvuna River catchment has surplus water available at the coast.

Based on the available information from the reconciliation strategy, the Weza Catchment has a water supply deficit as the available water from the two sources is not sufficient to meet the current water requirements. The current and future water requirements for domestic water use of Weza Harding Water Supply Scheme in UDM which depends on run-of-river abstraction from Weza River and a municipal dam near Harding cannot be supplied from the available water supplies without development of additional water supplies. This depends on the operating rules of the two sources of supply. There may be sufficient runoff during low flow periods from the municipal dam if it was operated only during low flow periods to meet the current water requirements of the scheme. However the water treatment works at Harding presents a limiting factor at a design capacity of 2.0 ML/d. However, during normal flows the Weza WTW, with a design capacity of 4.0 ML/d can supply the current water requirements of the water supply area. This however, cannot be done on a long term sustainable basis.

According to the WSDP, there are no known major water quality problems in the Weza Harding Water Supply Scheme area. It is however likely that the quality of the Weza and Mzimkhulwana Rivers is, however, significantly affected during periods of rainfall as a result of land use activities upstream, soil erosion and resulting increase in turbidity.

The geology and the topography of the area are such that there is no potential for significant groundwater development. Currently there is no groundwater use in the Weza Harding Water Supply Scheme area. There is no reported water quality problems associated with the groundwater.

The Weza Harding Water Supply Scheme comprises raw water abstraction from the Weza River as well as from the Mzimkhulwana Rivers, two water treatment works near Weza and Harding respectively and bulk service storage infrastructure and bulk distribution networks.

Water Treatment Works

Weza Water Treatment Works

The raw water from Weza River is pumped to the Weza WTW where it is treated to potable drinking water quality standards. The Weza WTW is the main treatment works that supplies the scheme area. The peak hydraulic design capacity of the water treatment works is only 4 ML/d or 1.5 million m³/a (WSDP, 2008). The average annual flow rate of the treatment works is estimated to be 2.7 ML/d or 1.0 million m³/a based on a peaking factor of 1.5.

The Weza WTW is a conventional treatment plant comprising the following process components:

- (i) *Flocculation channels*: The raw water is pumped from the Weza River to the inlet works where the chemicals are added as the water flows into the flocculation channels at the treatment works. Coagulation after polyelectrolyte dosing takes place to form the flocs.
- (ii) *Clarification (sedimentation) tanks*: The flocs that have formed during the flocculation process are then settled in the sedimentation tanks under gravity. The settled sludge is removed by frequent de-sludging of the tanks and sent to the sludge lagoons where the sludge is dried while the supernatant water is discharged back into the river. The plant was not designed for recycling of the wastewater.
- (iii) *Rapid Gravity Sand Filtration*: The clarified water is then filtered through a set of rapid gravity sand filters as a final polishing before chlorination of the treated water.
- (iv) *Disinfection*: The filtered water then gravitates to the chlorine contact tanks where chlorination takes place before pumping the potable water to the command reservoirs in Weza supply area for distribution.

Harding Water Treatment Works

The raw water from municipal dam in Harding is pumped to the Harding WTW where it is treated to potable drinking water quality standards. The Harding WTW is the secondary treatment works that supplies the scheme area. The peak hydraulic design capacity of the water treatment works is 2 ML/d or 0.73 million m³/a (WSDP, 2008). The average annual flow rate of the treatment works is estimated to be 1.33 ML/d or 0.49 million m³/a based on a peaking factor of 1.5. The type of treatment plant at Harding is not known.

The current utilization of the bulk water supply infrastructure is approximately 185%. The existing bulk water supply infrastructure does not have sufficient capacity to meet the current water requirements of Weza Harding Water Supply Scheme as well as the future water requirements on a long term sustainable basis.

Treatment Work Name	Type of plant	Raw water source	Hydraulic Design capacity (ML/d)	Average flow rate (ML/d)	Treated water production (ML/d)	Current utilisation (% of ave. design capacity)
Weza WTW Capacity	Conventional	Weza	4.00	2.67	5.42	203%
Harding WTW Capacity	Unknown	Mzimkulwana	2.00	1.33	2.00	150%
Total			6.00	4.00	7.42	185.5%

Table 10 - Water Treatment Works in operation in the Weza Water Supply Scheme area

(Source: First Stage Reconciliation Strategy for Weza Water Supply Scheme Area Umuziwabantu Municipality)

The condition and performance of the two treatment works is not known. It is also not known if the treatment works have been generally compliant with SANS 241, 2001 for potable drinking water quality standards.

Treated water bulk supply infrastructure

The treated water from the treatment works in the Weza Harding Water Supply Scheme is pumped from the clearwater tanks to various service reservoirs in the scheme area before distribution into the scheme's reticulation network (see table above). The pumping systems have standby capacity.

Bulk Storage

The total service storage capacity of the Weza Harding Water Supply Scheme area is not known to enable a determination of whether there is sufficient storage to the accepted norm of 48 hours of summer peak requirement for urban areas. This norm has been determined to meet the following requirements:

- Balance the fluctuating demands from the distribution system, permitting the source to give a steady or differently phased output;
- Provide a supply during a failure or shutdown of treatment plant, pumps or bulk mains leading to the reservoir; and
- Provide a reserve of water to meet fire and other emergency demands.

Therefore no conclusion could be drawn on whether additional service storage capacity is required currently or in the future. However as the demands grow in the scheme, additional service storage capacity will be required sometime in the future to meet the future summer peak requirements of Weza Harding Water Supply Scheme.




Figure 16 – Schematic layout of Weza Water Supply Scheme area
 (Source: First Stage Reconciliation Strategy for Weza Water Supply Scheme Area Umuziwabantu Municipality)

6. RECONCILIATION OF EXISTING AND PROPOSED WATER SUPPLY AND DEMAND OPTIONS

GIS analysis was used to calculate both high and low household counts, as well as high and low population counts, for each of the water supply footprint polygons. While the calculation of the household counts for each water supply footprint was a simple GIS query, the population statistics, and projection thereof, required more detailed analysis.

Household Counts:

Unique ID numbers were given to all the demand areas, which could then be used to link data from other sources. A spatial join was performed on the Eskom 2011 household points falling within each polygon. This gave each household point the unique ID of the area in which it fell. This data could then be summarised and a count done of the number of households in each area. This count was then added to the water demand attribute table.

Table			
footprint_pop_2014			
OID	UID	Cnt_UID	Sum_HH_2014
312	Ugu_134	5	9.2
313	Ugu_135	16	29.44
314	Ugu_14	947	4549.32
315	Ugu_140	7	54.18
316	Ugu_146	20	68.73
317	Ugu_15	1081	5121.41
318	Ugu_153	3	7.17
319	Ugu_157	11	26.29
320	Ugu_16	7421	31511.26
321	Ugu_160	17	52.08
322	Ugu_17	2887	14970.96
323	Ugu_178	14	36.47
324	Ugu_18	132	592.21
325	Ugu_181	161	383.65
326	Ugu_185	125	301.94
327	Ugu_19	576	3009.6
328	Ugu_2	1082	2766.5
329	Ugu_20	263	1454.84
330	Ugu_202	9	24.96
331	Ugu_204	7	22.19
332	Ugu_206	22	58.52
333	Ugu_21	8889	30875.97
334	Ugu_22	153	773.37
335	Ugu_220	4	18.8

Table 11 – Example of household data with unique water supply footprint identifier

These figures were used as the “Low” count, until the “High” had been calculated. The high count was obtained by extrapolating the growth rate for each ward from the Census 2001/2011 figure through to 2014. This information was obtained using the online Statistics SA Superweb application. Statistics SA was consulted on the best method in achieving these calculations. The 84 wards falling within Ugu District Municipality were selected, and the population figures for both 2001 and 2011 were added to the table. These two figures were used to calculate the percentage growth over that ten year period. The result was divided by 10 to get an average growth rate per annum for each ward.

This growth rate was then applied to the household count for each subsequent year (2012, 2013, 2014), and the result was used to populate the “High” values for both population and number of households in the attribute table. Once the high count had been completed, the two figures could be compared. Where “Low” > “High”, the figures were swapped. Since the calculations for high and low

demand for water were based on the required million m³ per annum, the number of decimal places in the household count was significant, and the project team made the decision to keep this to two decimal places.

Population Numbers:

Census 2011 data was used for the population figures. The Supercross programme was used to extract the household sizes and the total population counts for each subplace within the District. The total population was divided by the number of households (from the Eskom 2011 point data) to get the average household size.

Table												
hholds_with_UID_pop_growth_hhold_size												
Id	DM	UID	GrPA_2	Pop2012	Pop2013	Pop2014	Av_HHSize	OH_Cmmts	HH_2012	HH_2013	HH_2014	
96	Ugu	Ugu_96	1.13	6299.3877	6370.570781	6442.558231	5.92		5.99	6.06	6.13	
96	Ugu	Ugu_96	1.13	6299.3877	6370.570781	6442.558231	5.92		5.99	6.06	6.13	
96	Ugu	Ugu_96	1.13	6299.3877	6370.570781	6442.558231	5.92		5.99	6.06	6.13	
96	Ugu	Ugu_96	1.13	6299.3877	6370.570781	6442.558231	5.92		5.99	6.06	6.13	
96	Ugu	Ugu_96	1.13	6299.3877	6370.570781	6442.558231	5.92		5.99	6.06	6.13	
96	Ugu	Ugu_96	1.13	6299.3877	6370.570781	6442.558231	5.92		5.99	6.06	6.13	
96	Ugu	Ugu_96	1.13	6299.3877	6370.570781	6442.558231	5.92		5.99	6.06	6.13	
96	Ugu	Ugu_96	1.13	6299.3877	6370.570781	6442.558231	5.92		5.99	6.06	6.13	
96	Ugu	Ugu_96	1.13	6299.3877	6370.570781	6442.558231	5.92		5.99	6.06	6.13	
96	Ugu	Ugu_96	1.13	6299.3877	6370.570781	6442.558231	5.92		5.99	6.06	6.13	
96	Ugu	Ugu_96	1.13	6299.3877	6370.570781	6442.558231	5.92		5.99	6.06	6.13	
96	Ugu	Ugu_96	1.13	6299.3877	6370.570781	6442.558231	5.92		5.99	6.06	6.13	
96	Ugu	Ugu_96	1.13	6299.3877	6370.570781	6442.558231	5.92		5.99	6.06	6.13	
96	Ugu	Ugu_96	1.13	6299.3877	6370.570781	6442.558231	5.92		5.99	6.06	6.13	
96	Ugu	Ugu_96	1.13	6299.3877	6370.570781	6442.558231	5.92		5.99	6.06	6.13	
96	Ugu	Ugu_96	1.13	6299.3877	6370.570781	6442.558231	5.92		5.99	6.06	6.13	
97	Ugu	Ugu_97	0.27	8065.7188	8087.496241	8109.332481	3.73		3.74	3.75	3.76	
97	Ugu	Ugu_97	0.27	8065.7188	8087.496241	8109.332481	3.73		3.74	3.75	3.76	
97	Ugu	Ugu_97	0.27	8065.7188	8087.496241	8109.332481	3.73		3.74	3.75	3.76	
97	Ugu	Ugu_97	0.27	8065.7188	8087.496241	8109.332481	3.73		3.74	3.75	3.76	
97	Ugu	Ugu_97	0.27	8065.7188	8087.496241	8109.332481	3.73		3.74	3.75	3.76	
97	Ugu	Ugu_97	0.27	8065.7188	8087.496241	8109.332481	3.73		3.74	3.75	3.76	
97	Ugu	Ugu_97	0.27	8065.7188	8087.496241	8109.332481	3.73		3.74	3.75	3.76	
97	Ugu	Ugu_97	0.27	8065.7188	8087.496241	8109.332481	3.73		3.74	3.75	3.76	
97	Ugu	Ugu_97	0.27	8065.7188	8087.496241	8109.332481	3.73		3.74	3.75	3.76	
97	Ugu	Ugu_97	0.27	8065.7188	8087.496241	8109.332481	3.73		3.74	3.75	3.76	
97	Ugu	Ugu_97	0.27	8065.7188	8087.496241	8109.332481	3.73		3.74	3.75	3.76	
97	Ugu	Ugu_97	0.27	8065.7188	8087.496241	8109.332481	3.73		3.74	3.75	3.76	
97	Ugu	Ugu_97	0.27	8065.7188	8087.496241	8109.332481	3.73		3.74	3.75	3.76	
97	Ugu	Ugu_97	0.27	8065.7188	8087.496241	8109.332481	3.73		3.74	3.75	3.76	
97	Ugu	Ugu_97	0.27	8065.7188	8087.496241	8109.332481	3.73		3.74	3.75	3.76	
97	Ugu	Ugu_97	0.27	8065.7188	8087.496241	8109.332481	3.73		3.74	3.75	3.76	

This household size data was then linked to the household points, again using a spatial join in ArcGIS. Using the unique ID, the data was summarised and the number of people (a sum of the household size in each water supply footprint) was calculated. This was joined to the water supply footprint attribute table, and used as the low populatio count. In the same way as the growth of the number of households was calculated, the growth rate was applied to the population figures, and the result was again summarised, population figures summed, and this data added as the high population figure.

DM	HH_Low	HH_High	Pop_Low	Pop_High
Ugu	3	3	15	15
Ugu	4	4	20	20
Ugu	3	3	15	15
Ugu	29	33	93	104
Ugu	53	57	117	125
Ugu	23	26	125	140
Ugu	16	16	29	30
Ugu	47	53	96	109
Ugu	50	57	102	116
Ugu	7	7	22	22
Ugu	9	9	28	28
Ugu	4	4	13	13
Ugu	3	3	16	17
Ugu	7	8	38	42
Ugu	4	4	18	19
Ugu	13	15	42	47
Ugu	2783	2884	9248	9545
Ugu	20	21	66	69
Ugu	2556	2646	11570	12000
Ugu	199	215	884	954
Ugu	938	1013	4980	5383
Ugu	1325	1376	6214	6455
Ugu	30	32	145	153
Ugu	332	351	1788	1893
Ugu	1917	2112	8799	9694
Ugu	3326	3513	15713	16567
Ugu	469	530	1347	1525
Ugu	81	84	403	418
Ugu	475	520	1468	1610
Ugu	652	676	2764	2862
Ugu	963	998	2806	2898

Table 12 – Example of low and high household and population statistics

Water Demand Forecasts

The higher of the two household counts was used to calculate the low demand forecast (million m³ pa), using the figures supplied by the Department of Water Affairs using the All Town Study. The high demand forecast (million m³ pa) was calculated in the same way. The probable demand forecast (million m³ pa) was the average of these two figures.

DM	LowDemandForecast	HighDemandForecast	ProbableDemand	CurrentWaterRequirements	FutureWaterRequirements
Ugu	0.017651	0.033565	0.025006	0.025006	0.033565
Ugu	0.128597	0.205678	0.158067	0.158067	0.205678
Ugu	0.121063	0.229819	0.171506	0.171506	0.229819
Ugu	0.184354	0.290887	0.233515	0.233515	0.290887
Ugu	0.12229	0.237849	0.173244	0.173244	0.237849
Ugu	0.0491	0.095477	0.069558	0.069558	0.095477
Ugu	0.110069	0.221467	0.155932	0.155932	0.221467
Ugu	0.780297	1.705331	1.105421	1.105421	1.705331
Ugu	0.081556	0.162607	0.115537	0.115537	0.162607
Ugu	0.063247	0.104116	0.077741	0.077741	0.104116
Ugu	0.002234	0.003614	0.002829	0.002829	0.003614
Ugu	0.000591	0.000903	0.000749	0.000749	0.000903
Ugu	0.00184	0.002811	0.00233	0.00233	0.002811
Ugu	0.008344	0.012948	0.010569	0.010569	0.012948
Ugu	0.019644	0.030414	0.024883	0.024883	0.030414
Ugu	0.00887	0.013751	0.011235	0.011235	0.013751
Ugu	0.005782	0.008933	0.007323	0.007323	0.008933
Ugu	0.002694	0.004216	0.003412	0.003412	0.004216
Ugu	0.000854	0.001305	0.001082	0.001082	0.001305
Ugu	0.022294	0.042318	0.031583	0.031583	0.042318
Ugu	0.19526	0.314977	0.24733	0.24733	0.314977
Ugu	0.234286	0.462207	0.331905	0.331905	0.462207
Ugu	0.028295	0.054684	0.040084	0.040084	0.054684
Ugu	0.014366	0.027784	0.020352	0.020352	0.027784
Ugu	0.13797	0.257201	0.195458	0.195458	0.257201
Ugu	0.059831	0.115873	0.08476	0.08476	0.115873
Ugu	0.012439	0.02401	0.017622	0.017622	0.02401
Ugu	0.029762	0.047979	0.037699	0.037699	0.047979
Ugu	0.293197	0.542587	0.415363	0.415363	0.542587
Ugu	0.545354	1.047112	0.772585	0.772585	1.047112
Ugu	0.028908	0.055808	0.040953	0.040953	0.055808
Ugu	0.007884	0.013049	0.009986	0.009986	0.013049
Ugu	0.001971	0.003854	0.002792	0.002792	0.003854

Water Supply Status and Water Source

The supply status of each area was assessed using all available spatial water infrastructure data (boreholes, reservoirs, springs, pipelines etc.) and intersections with the water supply footprint polygons. Where there were intersections (i.e. there was some form of water supply within, or very close to water supply footprints) it was assumed that there was short term supply to that area. Assessments were checked manually to ensure that very close water supplies to settlement boundaries were taken into account.

Similarly, analysis using existing mapped boreholes and other water sources, was used to populate the existing water source field.

LOCAL MUNICIPALITY	NO OF WATER SUPPLY FOOTPRINTS	NO OF WATER SUPPLY FOOTPRINTS WITH SHORT TERM SUPPLY
Vulamehlo	36	22
Umdoni	24	22
Umzumbe	34	27
Umizwabantu	36	27
Ezingoleni	9	6
Hibiscus Coast	34	32
Ugu	173	136

6.1 Existing Water and Sanitation Infrastructure

Table 13 is a summary of the water infrastructure components within the UDM. This information was extracted from the WSDP which was undertaken in 2008.

Components	Total
Dams	5
Water mains	3896 km
Reservoirs	150
Pump stations	120
WTW	16
WWTW	10

Table 13 - Summary of water infrastructure components

(Source: WSDP 2008)

Table 14 is a summary of the sanitation infrastructure components within the UDM. This information was extracted from the WSDP which was undertaken in 2008.

Components	Total
VIP toilets	63 638
Septic tanks/conservancy tanks	19362
Bulk sewer	17800
New wastewater treatment works	6
Pump stations	30

Table 14 - Existing Sanitation Infrastructure

(Source: WSDP 2008 page 79)

6.2 Water and Sanitation Backlogs

Table 15 indicates the total number of households as well as water backlogs within the various local municipalities in the UDM.

Water	Total Households	Backlogs
Vulamehlo LM	12901	3420
Umdoni LM	13146	837
Umzumbe LM	26829	7080
Umuziwabantu LM	16093	2296
Ezingoleni LM	8757	873
Hibiscus Coast LM	42689	2034
Total	120414	16540

Table 15 - Water Backlogs

(Source: Eskom study 2011 and Stats SA)

Table 16 indicates the total number of households as well as sanitation backlogs within the various local municipalities in the UDM.

Sanitation	Total Households	Backlogs
Vulamehlo LM	12901	903
Umdoni LM	13146	920
Umzumbe LM	26829	1878
Umuziwabantu LM	16093	1126
Ezingoleni LM	8757	613
Hibiscus Coast LM	42689	2988
Total	120414	8429

Table 16 - Sanitation Backlogs
(Source: WSDP 2012/16 and Stats SA)

7. PROPOSED FUTURE SUPPLY OPTIONS

7.1 Existing proposals for future supply

UDM has developed a water master plan that seeks to integrate the 16 individual water schemes into sustainable systems, as follows:

- Harding Weza water supply scheme
- Umtamvuna water supply scheme
- UMzimbhulu water supply scheme
- Umtwalume water supply scheme
- Vulamehlo water scheme
- KwaLembe water scheme
- Mhlabashane water scheme
- South coast water transfer system from Inanda Dam

Table 17 indicates the projects/programmes for water supply projects in the various geographical areas, the targets (description of the work to be undertaken for these projects), budgets and the years of implementation. The table was extracted from the IDP undertaken in 2013.

PROJECT / PROGRAMMES	TARGET	BUDGET	TIME FRAME					GEOGRAPHICAL AREA
			2012/2013	2013/14	2014/15	2015/16	2016/17	
South Coast Augmentation Booster Pump Station	New in-line booster pump station (capacity = 120ML/day)	R86,680,000	Construction (R10,148,000)	Commissioning (R6,676,000)	0	0	0	eThekwini Municipality
Nungwane Raw Water Aqueduct	New 450mm diameter steel pipeline (capacity = 20ML/day)	R68,580,000	Design (R1,000,000)	Design (R2,500,000)	Construction (R1,500,000)	Construction (R42,000,000)	Construction (R21,580,000)	Vulamehlo LM ward 1 and eThekwini Municipality
South Coast Pipeline Phase 2A	4.5km South Coast Pipeline exte. Phase 1 (capacity = 35ML/day)	R38,368,000	Retention (R3,922,000)	0	0	0	0	Wards 4 and 10 of Umdoni Municipality
Ellingham Link Pipeline	3km long x 350mm diameter steel pipeline that links Scottburgh South Reservoir to Ellingham Reservoir. Scottburgh South Pump Station with two pump sets (one operating and one standby).	R36,500,000	Tender (R1,700,000)	Construction (R20,800,000)	Construction R14,000,000	0	0	Wards 4, 5 & 10 of Umdoni LM.

Mhlabatshane Bulk Water Supply Scheme (Phase 1)	Dam – 25m high composite earth embankment and central concrete spillway.	R182,120,000	Construction (R49,440,000)	0	0	0	0	Ward 3 of Umzumbe Municipality
	Raw water pump stations – at the dam and intermediate booster.							
Mhlabatshane Bulk Water Supply Scheme (Phase 1)	Raw water rising main – 400mm diameter steel pipeline.	R182,120,000	Construction (R49,440,000)	0	0	0	0	Ward 3 of Umzumbe Municipality
	WTP – 4ML/day upgrade to 8ML/day.							
	Potable water pump station.							
	Potable water rising main – 350mm diameter uPVC pipeline.							
	Reservoir – 2ML upgrade to 4ML.							

	Potable water gravity main: 200mm diameter uPVC							
Lower Mkomazi Bulk Water Supply Scheme	This scheme will receive raw water from the lower Mkomazi River for treatment and distribution into the South Coast Pipeline. Potable water would be fed northwards to the Upper South Coast region and Amanzimtoti, and southwards to the Middle South Coast region. This would then allow the Amanzimtoti & Craigieburn WTPs to be fully decommissioned	R796,000,000	0	0	Planning (R2,500,000)	Planning (R3,500,000)	0	eThekwini Municipality and Ugu District Municipality
East Coast	Inlet and outlet	R18,000,000	Feasibility	Feasibility	N/A	N/A	N/A	eThekwini

Desalination Plants	works, bulk supply infrastructure, 150ML/day reverse osmosis desalination plant.		(R11,791,000)	(R4,500,000)				Municipality
South Coast Pipeline Phase 2B	New 600mm diameter x 5km long steel pipeline from Kelso Off-take to Pennington Reservoir	R40,000,000.00	N/A	Feasibility (R3,000,000)	Design & Construction (R37,000,000)	N/A	N/A	Ward 10 of Umdoni Municipality

Table 17 – Projects/programmes for water supply projects

(Source: IDP 2013)

Figure 17 indicates the planned bulk pipelines and reticulation projects within the Ugu District Municipality. This figure was extracted from the IDP undertaken in 2013.

Figure 19 indicates the existing and completed water projects within the Ugu District. It indicates all existing reservoirs, water treatment works and water pipelines. This figure was extracted from the IDP undertaken in 2013.

The maps on pages 76-81 indicate the various projects in each Local Municipality, the funding agent, status of the projects and total project cost. These drawings were sourced from Bigen Africa

The GIS provided by the UDM indicated their proposed water supply schemes. Where possible the concept designs were tied into the UDM's planned network to avoid any duplication of infrastructure and reduce costs.

The quantification and pricing undertaken in this report is based on UAP proposals only and does not take into consideration the future infrastructure already planned by the UDM as it is assumed that funding for these proposals have already been secured by UDM.




Figure 17 – Ugu District Planned & Currently Under Construction Water & Sanitation Projects
 Source (IDP 2013)






Figure 18 – Ugu District Completed & Existing Projects
(Source: IDP 2013)

UGU - VULAMEHLO




UGU - UMDONI




Project Number	Apps Class	IP Class	Project Name	Project Status	Project Origin	Total Project Cost
2011MIGFDC21202619	3	3	Non Revenue Water Reduction Project	Planning	MIG	R 9 106 200.00
2012MIGFDC21205402	3	3	Meter Replacement Program	Planning	MIG	R 13 950 000.00
2012MIGFDC21205831	1	2	Umzinto Slum Clearance: Farm Isonti Low cost Housing Water and Sanitation Scheme	Feasibility	MIG	R 77 822 259.00
2012MIGFDC21207776	3	3	Water Pipeline Replacements	Planning	MIG	R 705 000 000.00
ZKZNUGU19	1	2	Isonti Farm - Bulk Services	Tender	Other	R 70 000 000.00
ZKZNUGU28	1	2	Qoloqolo Water Supply	Feasibility	Other	R 140 000 000.00
ZKZNUGU32	3	3	Water Pipeline Replacements	Planning	23DM	R 200 000 000.00


UGU - UMZUMBE




UGU - UMUZIWABANTU



UGU - EZINGOLENI



UGU - HIBISCUS COAST



8. APPROACH TO WATER SUPPLY

8.1 Water Treatment Works Situation Analysis

Vulamehlo Local Municipality

Current Population	= 77403
Consumption based on 70l/c/d	= 5.72 ML/d
Total Capacity of existing water treatment plants	= 6.25 ML/d

Vulamehlo Local Municipality is served by Kwalembe WTW (2.50 ML/d), Vulamehlo (Jolivet) WTW (3 2.25 ML), Breemar WTW (1.50 ML/d) and Boreholes (0.72 ML/d).

Total Capacity of existing water treatment works	= 6.97 ML/d
--	-------------

Hence the calculation above indicates that there is insufficient water treatment capacity in the Vulamehlo Local Municipality currently.

Umdoni Local Municipality

Current Population	= 78875
Consumption based on 70l/c/d	= 5.52 ML/d

Umdoni Local Municipality is served by Umzinto WTW (13.60 ML/d).

Total Capacity of existing water treatment plants	= 13.60 ML/d
---	--------------

Hence the calculation above indicates that there is sufficient water treatment capacity in the Umdoni Local Municipality currently.

Umzumbe Local Municipality

Current Population	= 160975
Consumption based on 70l/c/d	= 11.27 ML/d

Umzumbe Local Municipality is served by Ndelu WTW (2.10 ML/d), Pungase WTW (0.45 ML), KwaHongwa WTW (1.13 ML/d), Umtwalume WTW (4.50 ML), Umtwalume Upgrade WTW (4.50 ML) and Boreholes (1.44 ML/d).

Total Capacity of existing water treatment plants	= 14.12 ML/d
---	--------------

Hence the calculation above indicates that there is sufficient water treatment capacity in the Umzumbe Local Municipality currently.

Umuziwabantu Local Municipality

No information currently available on Water Treatment Plants in the Umuziwabantu Municipality.

Ezingoleni Local Municipality

No information currently available on Water Treatment Plants in the Ezingoleni Municipality.

Hibiscus Local Municipality

Current Population = 256135

Consumption based on 70l/c/d = 17.93 ML/d

Hibiscus Coast Local Municipality is served by Umtamvuna WTW (20.0 ML/d) and Bobhoyi WTW (54.0 ML).

Total Capacity of existing water treatment plants = 70.0 ML/d

Hence the calculation above indicates that there is sufficient water treatment capacity in the Hibiscus Coast Local Municipality currently.

8.2 Design Parameters

MM PDNA undertook the conceptual design for the whole district municipality and divided it into each local municipality for that district municipality. The following assumptions were made in undertaking the conceptual design:

- Each household has an average of 6 people.
- Low water demand to be 70 liters per capita per day.
- High water demand to be 120 liters per capita per day.
- The existing boreholes are functional.
- The existing water reticulation schemes are operational.
- The existing water reticulation schemes have spare capacity.
- Water Treatment Works have the potential to be upgraded or rehabilitated.
- Schemes have some form of power supply.
- General pipe size range is from 25 mm to 150 mm diameter.
- Peak factor - 1.5
- Proposed reservoirs storage based on 48 hours water consumption
- Velocity range is between 0.7m/s per second to 1.5 m/s
- Pressure at standpipes/supply point – Average 6m of head
- Water losses were considered to be 35%
- Where there is an existing bulk line, connections to the bulk were kept to a minimum
- Reticulation mains were placed in the road reserve so that it can be maintained
- District and provincial road crossings were kept to a minimum

8.3 Scheme Types

MMPDNA assessed some of the existing water supply options that the UDM currently implements and applied the same scheme types to supply the un-serviced polygons. The following schemes were adopted by MMPDNA to determine the type of scheme applicable to the different settlements and their associated costs which was provided by Umgeni Water.

- Tie into existing scheme.
- Existing boreholes and standpipes that is non-functional to be rehabilitated.
- Existing boreholes with a reticulation to be rehabilitated.
- Boreholes mechanically operated for settlements with a low population.
- Boreholes electronically operated for settlements with a high population.
- Small Package Plants for density populated settlements.
- From existing scheme pumped to new reservoir and reticulated.

- Where the existing borehole schemes are indicated but the settlement households are still indicated as un-serviced. We assumed that there was an issue with the existing boreholes and have therefore linked to the contiguous water supply schemes. Figure 19 below indicates this principle.




Figure 19 - Existing Borehole Schemes not in operation

8.3.1 Link to existing scheme

Areas without supply that are adjacent to existing water mains will be supplied by extending the existing reticulation to the new area that requires water supply.


- Assumption in viewing the polygons, we found existing boreholes, however there was no supply to the existing community. Hence it was further assumed that the existing boreholes were non-functional possibly due to the pumps not working or the aquifer being dry.

The GIS information indicated a bulk supply line indicated contiguous to the community which was used to supply the area.

- In some cases the GIS information indicates that there is an existing bulk line, however there are un-serviced households contiguous to the bulk line, it was assumed that they are un-serviced due to the households being at a higher elevation.


These households were serviced by undertaking a pumping main from the existing bulk to a new reservoir at a higher elevation where it can be gravity fed to the households. It was assumed to be a cost effective option.

In areas where the static head exceeds 100m, break pressure tanks should be constructed to reduce the pressure and also create additional storage.




8.3.2 Refurbishment of mechanical boreholes

Existing mechanical boreholes that previously supplied water to a community is now defunct due to the pump no longer functioning and hence a replacement pump needs to be installed to ensure the continued delivery of water.



8.3.3 Refurbishment of electrical boreholes


Existing electrical boreholes that previously supplied water to a community is now defunct due to the pump or motor no longer functioning and hence a replacement pump or motor needs to be installed to ensure the continued delivery of water.



8.3.4 New mechanical boreholes


Mechanical boreholes are installed in remote rural areas where there is no available water reticulation and electrical supply.

Our view was that where the population was between 20-30 people mechanical boreholes would be the most cost effective supply of water. Other forms of installing boreholes would be by installing windmills.



8.3.5 New electrical boreholes


Electrical boreholes are installed in remote rural areas where there is no available water reticulation and where electrical supply is available.



8.3.6 Existing Scheme pumped to new elevated tank and reticulated

Areas without supply are at elevations higher than the existing reticulation and cannot be supplied by the existing reticulation due to the height difference.


This option proposes to supply the houses at the higher elevation by obtaining water from the existing mains and installing a wet well and a pump station as well as an elevated reservoir.



8.3.7 New Package Water Treatment Works

Areas which are close to a river source are supplied by a containerized package treatment plant which abstract water from the river.


This option proposes to abstract water from the river through the package plant which has flocculation units clarification units and filtration units. The water is pumped via a pump station to the storage reservoir which has a chlorination unit installed.



8.4 Description and mapping of supply schemes

Concept layouts of the proposed infrastructure have been included in the GIS database. The names of the names of the schemes in the tables in section 7.5 refer to individual water supply footprints and these names have been indicated on the aforementioned database. Drawings/mapping indicating the schemes is attached in a CD. The GIS report undertaken by MHP gives a detailed description of the database.

The Ugu District Municipality area was plotted in a map series produced at a scale of 1:20 000. Existing and proposed infrastructure, together with the water supply footprints and contour information (20m intervals) were overlaid onto aerial photography and both exported to pdf and plotted.




Map 7 – Example of map series sheet

These maps were used, together with the population statistics already calculated, by the engineers at MM PDNA, who designed conceptual water supply schemes directly onto the hard copy maps. These maps were returned to MHP GeoSpace, and the concept water pipelines and other infrastructure (standpipes, boreholes, reservoirs etc.) were digitised into the GIS.

New feature classes were added to the geodatabase and lookup tables assigned to fields within the feature classes. This ensured consistency throughout the data capture process, as it meant that there would be no difference in the type of features captured by different users. The digitised infrastructure was checked to ensure that there was consistency between and across the different map sheets. Each individual map sheet was also checked to ensure that all data had been captured.

Where the conceptual water infrastructure was designed and captured (i.e. where there was no existing supply infrastructure) the settlement (water demand) polygon was assigned a unique identifier. This identifier was captured to a separate data set (costed water supply areas) which could later be linked back to the costing model used by the engineers.



Map 8 – Example of data captured from engineers drawings

8.5 Cost Estimates for Proposed Infrastructure

The rates provided by Umgeni Water are shown on the tables below:

Reservoir

0.25	ML	R 1 381 197
0.5	ML	R 2 243 761
0.75	ML	R 2 980 166
1	ML	R 3 645 000
1.25	ML	R 4 261 226
1.5	ML	R 4 841 294
1.75	ML	R 5 392 922
2	ML	R 5 921 320
2.25	ML	R 6 430 212
2.5	ML	R 6 922 382
2.75	ML	R 7 399 978
3	ML	R 7 864 705
3.25	ML	R 8 317 942
3.5	ML	R 8 760 828
3.75	ML	R 9 194 316
4	ML	R 9 619 213
4.25	ML	R 10 036 211
4.5	ML	R 10 445 910
4.75	ML	R 10 848 834
5	ML	R 11 245 442
5.25	ML	R 11 636 143
5.5	ML	R 12 021 299
5.75	ML	R 12 401 237
6	ML	R 12 776 250
6.25	ML	R 13 146 603
6.5	ML	R 13 512 537
6.75	ML	R 13 874 271
7	ML	R 14 232 007
7.25	ML	R 14 585 930
7.5	ML	R 14 936 210
7.75	ML	R 15 283 004
8	ML	R 15 626 457
8.25	ML	R 15 966 705
8.5	ML	R 16 303 873
8.75	ML	R 16 638 079
9	ML	R 16 969 431
9.25	ML	R 17 298 034
9.5	ML	R 17 623 983
9.75	ML	R 17 947 368
10	ML	R 18 268 275
10.25	ML	R 18 586 783

Pump Station (Civil, Mech and Elec)

0.25	MW	R 11 000 000
0.5	MW	R 18 000 000
0.75	MW	R 25 000 000
1	MW	R 33 000 000
1.25	MW	R 44 000 000
1.5	MW	R 55 000 000
1.75	MW	R 66 000 000
2	MW	R 77 000 000

Pump Station Expansion (Mech and Elec)

0.25	MW	R 3 750 000
0.5	MW	R 7 500 000
0.75	MW	R 11 250 000
1	MW	R 15 000 000
1.25	MW	R 18 750 000
1.5	MW	R 22 500 000
1.75	MW	R 26 250 000
2	MW	R 30 000 000

Water Works

0-50	ML/d	R 4 000 000
50-100	ML/d	R 2 500 000
100-1000	ML/d	R 2 000 000

Water Works Augmentation

0-50	ML/d	R 1 800 000
50-200	ML/d	R 1 500 000

Pipes Steel (mm Ø)

150	mm	R 550
200	mm	R 600
300	mm	R 700
350	mm	R 800
400	mm	R 900
450	mm	R 1 300
500	mm	R 1 650
600	mm	R 1 980
700	mm	R 2 500
800	mm	R 3 200
850	mm	R 3 350
1000	mm	R 3 971

10.5	ML	R 18 902 970	1100	mm	R 4 075
10.75	ML	R 19 216 906	1200	mm	R 4 500
11	ML	R 19 528 659	1300	mm	R 6 065
11.25	ML	R 19 838 293	1400	mm	R 6 900
11.5	ML	R 20 145 870	1600	mm	R 8 500
11.75	ML	R 20 451 447	1800	mm	R 9 563
12	ML	R 20 755 080			
12.25	ML	R 20 056 820			
12.5	ML	R 21 356 719	75	mm	R 100
12.75	ML	R 21 654 824	100	mm	R 140
13	ML	R 21 951 180	200	mm	R 250
13.25	ML	R 22 245 832	300	mm	R 350
13.5	ML	R 22 538 820			
13.75	ML	R 22 830 185			
14	ML	R 23 119 964			
14.25	ML	R 23 408 196			
14.5	ML	R 23 694 914	150	mm	R 858
14.75	ML	R 23 980 153	200	mm	R 936
15	ML	R 24 263 945	300	mm	R 1 091
15.25	ML	R 24 546 322	350	mm	R 1 247
15.5	ML	R 24 827 313	400	mm	R 1 403
15.75	ML	R 25 106 948	450	mm	R 2 027
16	ML	R 25 385 254	500	mm	R 2 573
16.25	ML	R 25 662 259	600	mm	R 3 087
16.5	ML	R 25 937 989	700	mm	R 3 898
16.75	ML	R 26 212 467	800	mm	R 4 990
17	ML	R 26 485 720	850	mm	R 5 224
17.25	ML	R 26 757 769	1000	mm	R 6 192
17.5	ML	R 27 028 638	1100	mm	R 6 354
17.75	ML	R 27 298 349	1200	mm	R 7 017
18	ML	R 27 566 923	1300	mm	R 9 457
18.25	ML	R 27 834 379	1400	mm	R 10 759
18.5	ML	R 28 100 739	1600	mm	R 13 254
18.75	ML	R 28 366 021	1800	mm	R 14 910
19	ML	R 28 630 244			
19.25	ML	R 28 893 426			
19.5	ML	R 29 155 585			
19.75	ML	R 29 416 737			
20	ML	R 29 676 900			
20.25	ML	R 29 936 088			
20.5	ML	R 30 194 319			
20.75	ML	R 30 451 606			
21	ML	R 30 707 965			
21.25	ML	R 30 963 410			
21.5	ML	R 31 217 955			

Pipes Plastic (mm Ø)

Fittings and Auxiliaries

Pipes Installation (mm Ø)

21.75	ML	R 31 471 614
22	ML	R 31 724 399
22.25	ML	R 31 976 325
22.5	ML	R 32 227 402
22.75	ML	R 32 477 644
23	ML	R 32 727 062
23.25	ML	R 32 975 668
23.5	ML	R 33 223 474
23.75	ML	R 33 470 489
24	ML	R 33 716 726
24.25	ML	R 33 962 195
24.5	ML	R 34 206 906
24.75	ML	R 34 450 869
25	ML	R 34 694 093
25.25	ML	R 34 936 589
25.5	ML	R 35 178 366
25.75	ML	R 35 419 432
26	ML	R 35 659 798
26.25	ML	R 35 899 471
26.5	ML	R 36 138 460
26.75	ML	R 36 376 774
27	ML	R 36 614 421
27.25	ML	R 36 851 408
27.5	ML	R 37 087 744
27.75	ML	R 37 323 436
28	ML	R 37 558 493
28.25	ML	R 37 792 920
28.5	ML	R 38 026 726
28.75	ML	R 38 259 917
29	ML	R 38 492 501
29.25	ML	R 38 724 484
29.5	ML	R 38 955 873
29.75	ML	R 39 186 675
30	ML	R 39 416 895

8.5.1 Proposed Short Term Supply Schemes

The tables below show the cost estimate for short term schemes which tie into the existing reticulation.

Scheme Name	Cost
A9-1	R 3 956 957

A9 – Refers to the drawing number (i.e drawings on the attached CD)

1 – Refers to the scheme number on the associated drawing

Each scheme number has an associated cost which is also captured on the GIS database.

The cost estimates is based on providing a UAP service only. The upgrading of existing works or rehabilitation of existing water infrastructure has not been included in the cost estimates. The estimates exclude all operation and maintenance costs.

The cost estimates cover the price of undertaking the construction of the water scheme as well as professional fees for the following: geotechnical engineering fees, environmental fees and engineering fees.

In some cases the GIS picked up single scattered houses which are shown to be un-serviced within a polygon which is serviced. It is assumed that these houses came about after the construction of the water supply in that area. For the purpose of the conceptual design and cost estimates these houses were supplied with standpipes by connecting into the existing water reticulation infrastructure and it was not considered to be an anomaly.

8.5.1.1 Vulamehlo Local Municipality

Scheme Name	Cost
Link to existing	
A9-1	R 3 956 957
A10-1	R 7 005 346
B7-1	R 11 053 222
B8-1	R 24 810 395
B9-1	R 28 871 138
B10-1	R 56 447 175
C7-1	R 29 047 305
C8-1	R 34 365 188
C9-1	R 29 879 203
D6-1	R 6 086 134
D7-2	R 22 095 646
D8-3	R 15 469 048
D9-1	R 12 178 622
D7-1	R 9 895 253
TOTAL	R 291 160 632

8.5.1.2 Umdoni Local Municipality

Scheme Name	Cost
Link to existing	
C10-1	R 3 613 311
D10-1	R 6 299 469
E9-1	R 31 641 751
TOTAL	R 41 554 530

8.5.1.3 Umzumbe Local Municipality

Scheme Name	Cost
Link to existing	
E4-1	R 2 440 625
E5-1	R 8 026 277
F9-1	R 2 101 268
E6-1	R 24 421 003
G6-1	R 15 043 807
E7-1	R 68 960 184
E8-1	R 53 141 024
F5-1	R 8 730 724
F6-1	R 66 117 872
F7-1	R 118 613 477
F8-1	R 75 706 864
TOTAL	R 443 303 125

8.5.1.4 Umuziwabantu Local Municipality

Scheme Name	Cost
Link to existing	
G1-2	R 2 578 084
G2-1	R 39 204 825
G3-1	R 6 849 303
H2-1	R 29 191 911
H3-1	R 15 619 373
G5-1	R 5 610 747
H4-1	R 16 995 387
F4-1	R 29 031 728
G4-1	R 28 712 236
TOTAL	R 173 793 594

8.5.1.5 Ezingoleni Local Municipality

Scheme Name	Cost
Link to existing	
H6-1	R 15 775 526
G5-H5-H4	R 133 893 472
I5-1	R 49 661 675
I4-2	R 21 189 299
TOTAL	R 220 519 973

8.5.1.6 Hibiscus Coast Local Municipality

Scheme Name	Cost
Link to existing	
I6-1	R 87 203 404
K5-1	R 6 849 303
K6-1	R 2 028 250
I7-1	R 5 676 617
J5-1	R 20 152 643
J6-1	R 29 214 784
H7-1	R 10 370 219
G8-1	R 23 281 142
G7-1	R 32 886 025
TOTAL	R 217 662 386

Summary of Short Term Supply Schemes

Municipality	Total Cost
Vulamehlo	R 291 160 632
Umdoni	R 41 554 530
Umzumbe	R 443 303 125
Umuziwabantu	R 173 793 594
Ezingoleni	R 220 519 973
Hibiscus Coast	R 217 662 386
TOTAL	R 1 387 994 240

8.5.2 Proposed Long Term Supply Schemes

8.5.2.1 Vulamehlo Local Municipality

Scheme Name	Cost	Total
New Borehole mechanically operated		R 5 881 260
D8-1	R 2 940 630	
D8-4	R 2 940 630	
New Borehole electronically operated		R 9 652 359
C8-2	R 3 285 706	
D8-2	R 3 148 247	
D9-2	R 3 218 406	
TOTAL		R 15 533 619

Cost per capita = R 14 946

8.5.2.2 Umuziwabantu Local Municipality

Scheme Name	Cost	Total
New Borehole electronically operated		R 9 169 825
F1-1	R 3 010 789	
F1-2	R 3 079 518	
G1-1	R 3 079 518	
TOTAL		R 9 169 825

Cost per capita = R 13 281

8.5.2.3 Ezingoleni Local Municipality

Scheme Name	Cost	Total
New Borehole electronically operated		R 3 285 706
I4-1	R 3 285 706	
Total		R 3 285 706

Cost per capita = R 42 727

Summary of Long Term Supply Schemes

Municipality	Total Cost
Vulamehlo	R 15 533 619
Umuziwabantu	R 9 169 825
Ezingoleni	R 3 285 706
TOTAL	R 27 989 150

The cost per capita for each of the local municipalities is indicated in the table below. The cost per capita includes the short term and long term supply schemes and is based on an average of 6 people per household.

Local Municipality	Cost per capita
Vulamehlo	R 14 946
Umdoni	R 8 274
Umzumbe	R 10 436
Umuziwabantu	R 13 281
Ezingoleni	R 42 727
Hibiscus Coast	R 17 835

8.6 Phasing of scheme options

The phasing includes proposed plans to address the water backlogs. Various potential funding such as MIG, PIG etc. may be applied for to undertake these projects. The phasing is based on both the short and long term proposals.

An average cost for each scheme type was compared with the cost estimate for an individual scheme. If the scheme was less than or equal to the average it was assumed that the project could be undertaken over a year. If the cost ratio was higher than the average cost, the ratio was used to determine the duration of the project. However, this is flexible depending on the nature and type of project.

An example of the above explanation is demonstrated as follows for the scheme type link to existing for the Vulamehlo Local Municipality.

Scheme Name	Cost
Link to existing	
A9-1	R 3 956 957
A10-1	R 7 005 346
B7-1	R 11 053 222
B8-1	R 24 810 395
B9-1	R 28 871 138
B10-1	R 56 447 175
C7-1	R 29 047 305
C8-1	R 34 365 188
C9-1	R 29 879 203
D6-1	R 6 086 134
D7-2	R 22 095 646
D8-3	R 15 469 048
D9-1	R 12 178 622
D7-1	R 9 895 253
TOTAL	R 291 160 632

The total number of schemes is 14.

The total cost of the 14 schemes is R 291 160 632.

The average cost per scheme is $R 291 160 632 / 15 = R 20 797 188$.

To phase scheme B10-1 which costs R 56 447 175, is $R 56 447 175 / R 20 797 188 = 2.7$, hence scheme B10-1 is phased to be undertaken in three years.

To phase scheme C8-1 which costs R 34 365 188, is $R 34 365 188 / R 20 797 188 = 1.7$, hence scheme C8-1 is phased over two years.

The phasing of the schemes is indicated in Table 18.

Implementation Year	LM	Total Cost
2015/16	Vulamehlo	R 210 000 628
	Umdoni	R 9 912 780
	Umzumbe	R 113 904 727
	Umuziwabantu	R 85 534 954
	Ezingoleni	R 89 912 206
	Hibiscus Coast	R 130 458 982
	TOTAL	R 639 724 277

Implementation Year	LM	Total Cost
2016/17	Vulamehlo	R 40 246 448
	Umdoni	R 31 641 751
	Umzumbe	R 210 784 920
	Umuziwabantu	R 97 428 465
	Ezingoleni	R 133 893 472
	TOTAL	R 513 995 056

Implementation Year	LM	
2017/18	Vulamehlo	R 56 447 175
	Umzumbe	R 118 613 477
	TOTAL	R 175 060 652

Implementation Year	LM	
2018/19	Hibiscus Coast	R 87 203 404
	TOTAL	R 87 203 404

Table 18 - Phasing of Schemes

9. DEVELOP AN UPDATED GEO DATABASE INCLUDING META DATA OF ALL RELEVANT INFORMATION

All the GIS infrastructure data, both existing and proposed, together with the water supply footprint areas has been incorporated into a structured geodatabase. All fields requested in the terms of reference, whether populated or not, have been included in the attribute tables of each dataset. Metadata for each dataset has been captured (for the entire dataset), and within the attribute table, metadata fields applicable to specific fields have also been included. These include metadata on the source of the population statistics, the water source data, and the connection type data.

A “completeness” field has also been included in the feature class for the water supply footprints. This field gives a snapshot view of the percentage completeness of all the fields in the dataset for each area.

Other data included in the geodatabase are administrative boundaries (wards, local municipalities, district municipalities) together with locality features such as place names and neighbouring countries. Both urban and cadastral data from the Surveyor General’s Office has been included. Social facilities including health facilities and schools have been provided, both to assist with water planning needs, as well as informing about the area in which the user is working.

All household information has been added to the geodatabase – Eskom household points as well as the DRDLR settlement boundaries. Topography in the form of 20m contours from the 1:50 000 topographic map series were used in the planning process, and can be found in the geodatabase. Rivers and road network data has also been included.

Along with all the base data, infrastructure specific to the District Municipality has been imported. The geodatabase also contains the data which has been captured during this project. The water supply footprints, proposed water pipelines and proposed water features (boreholes, standpipes etc.) have been added to the geodatabase.

A detailed list of all the datasets, along with their metadata can be found in Annexure 1. An outline of the GIS methodology can be found in Annexure 2.

DVD’s containing all spatial information, along with files of all working maps, as well as the map series showing the planned service infrastructure, have been provided along with this report. A series of A0 maps have also been prepared and exported to pdf which can be viewed in Annexure 3. One map shows the entire district municipality, with others showing each of the local municipalities within the district.

10. CONCLUSION AND RECOMMENDATIONS

10.1 Total cost of proposed schemes in the Ugu District Municipality

The following table gives an indication in the form of a summary of the proposed conceptual scheme types and the associated costs which need to be undertaken to alleviate the current water backlog of 16540 households in the Ugu District Municipality.

Ugu DM	
Scheme Type	Total
Link to Existing Scheme	R 1 387 994 240
New boreholes mechanically operated	R 5 881 260
New boreholes electronically operated	R 22 107 890
TOTAL	R 1 415 983 390

10.2 Total cost of phases of schemes in the Ugu District Municipality

An average cost for each scheme type was compared with the cost estimate for an individual scheme. If the scheme was less than or equal to the average it was assumed that the project could be undertaken over a year. If the cost ratio was higher than the average cost, the ratio was used to determine the duration of the project. However, this is flexible depending on the nature and type of project. A detailed description of the phasing can be viewed in section 8.6 of the report.

The proposed conceptual design schemes may be phased according to the tables below.

Implementation Year	LM	Total Cost
2015/16	Vulamehlo	R 210 000 628
	Umdoni	R 9 912 780
	Umzumbe	R 113 904 727
	Umuziwabantu	R 85 534 954
	Ezingoleni	R 89 912 206
	Hibiscus Coast	R 130 458 982
	TOTAL	R 639 724 277

Implementation Year	LM	Total Cost
2016/17	Vulamehlo	R 40 246 448
	Umdoni	R 31 641 751
	Umzumbe	R 210 784 920
	Umuziwabantu	R 97 428 465
	Ezingoleni	R 133 893 472
	TOTAL	R 513 995 056

Implementation Year	LM	
2017/18	Vulamehlo	R 56 447 175
	Umzumbe	R 118 613 477
	TOTAL	R 175 060 652

Implementation Year	LM	
2018/19	Hibiscus Coast	R 87 203 404
	TOTAL	R 87 203 404

10.3 Proposed Future Work

It is recommended that the concept designs covered in this report be advanced to preliminary designs.

It is recommended that the link to existing schemes for the various local municipalities be undertaken first due to the existing water treatment and bulk infrastructure. The table below is a summary of the cost of the link to existing schemes that can be undertaken.

Link to existing schemes	
Local Municipality	Total
Vulamehlo	R 291 160 632
Umdoni	R 41 554 530
Umzumbe	R 443 303 125
Umizwabantu	R 173 793 594
Ezingoleni	R 220 519 973
Hibiscus Coast	R 217 662 386
Total	R 1 387 994 240

11. ANNEXURES

Annexure 1 - Database Design and attribute table

GEODATABASE STRUCTURE/DATA DICTIONARY

BASE DATA

FEATURE DATASET	FEATURE CLASSES	DESCRIPTION	SOURCE
Administration	District Municipalities 2011	District municipality boundaries from 2011	Demarcation Board
	Local Municipalities 2011	Local municipality boundaries from 2011	Demarcation Board
	Neighbouring Countries	Borders of neighbouring countries	SA Atlas
	Ocean	Dataset created to show ocean next to KZN coast	MHP GeoSpace
	Place Names	Main place names within KZN	SA Atlas
	RSA	Provincial boundaries	Demarcation Board
	Subplace Names	Subplace names from centroids of polygon data	Statistics SA
	Wards 2011	Ward boundaries from 2011	Demarcation Board
Cadastral	Urban cadastral	Urban cadastral data	Surveyor General's Office, PMB
	Farm portions cadastral	Farm portion cadastral data	Surveyor General's Office, PMB
Facilities	Education facilities	Point dataset showing location of all schools	KZN Department of Education
	Health facilities	Point dataset showing location of all health facilities	KZN Department of Health
Hydrology	Major rivers	Major rivers within KwaZulu-Natal	Department of Water Affairs
	Minor rivers	Minor rivers within KwaZulu-Natal	Department of Water Affairs
Settlement	Households	2011 household points	Eskom
Topography	Contours 20m	Contours at 20m intervals	National Geospatial Information
Transport	DOT 2014	All roads (major and minor) from 2014	Department of Transport

INFRASTRUCTURE			
Infrastructure	Pumps	Point dataset showing existing pumps	Department of Water Affairs; District and Local Municipalities
	Supply Source	Point dataset showing existing water sources including boreholes and springs	Department of Water Affairs; District and Local Municipalities
	Waste Water Treatment Works	Point dataset showing existing waste water treatment works	Department of Water Affairs; District and Local Municipalities
	Water Meters	Point dataset showing existing water meters	Department of Water Affairs; District and Local Municipalities
	Water Pipelines	Line dataset showing existing water pipelines – bulk and reticulation	Department of Water Affairs; District and Local Municipalities
	Water Reservoirs	Point dataset showing existing reservoirs	Department of Water Affairs; District and Local Municipalities
	Water Treatment Works	Point dataset showing existing water treatment works	Department of Water Affairs; District and Local Municipalities

UAP			
UAP	UAP Demand Areas	Digitised footprints around settlements in the District Municipalities within the project	MHP GeoSpace
	UAP Water Nodes	Digitised water nodes (boreholes, standpipes etc) captured off hard copy maps	MM PDNA/MHP GeoSpace
	UAP Water Lines	Digitised water pipelines captured off hard copy maps	MM PDNA/MHP GeoSpace

WATER SUPPLY FOOTPRINTS ATTRIBUTES

Field Name	Alias	Description	Units/Values/ Field Type
DM	District Municipality	Name of the municipality in which the area falls	Text
Area_m2	Area in square metres	GIS calculated	Number
Name	Name	Name of area if known	Text
Short_SS	Short term supply status	Is there an existing supply?	Y/N lookup table
Interim_SS	Interim supply status	Is there an interim supply?	Y/N lookup table
Bulk_SS	Bulk supply status	Is there a bulk supply?	Y/N lookup table
ST_Supply	Sustainable supply	Is the supply sustainable?	Y/N lookup table
Sust_2016	Sustainable to 2016	Is existing supply sustainable to 2016?	Y/N lookup table
Not_2016	Not sustainable to 2016	If N, What needs to be done to ensure sustainable supply to 2016?	Text
ExistPlans	Existing plans	Are there existing plans to ensure sustainably beyond 2016?	Y/N lookup table
Horizon30	30 year horizon plans	If Y, are these plans for 30 year horizon?	Y/N lookup table
Plans30yr	Detail of plans	If Y, what are these plans.	Text
Sust2046	Sustainable to 2046	If N, What needs to be done to ensure sustainable supply to 2046?	Text
Schm_E	Existing scheme name	Name of any existing supply scheme	Text
Schm_F	Future scheme name	Name of any future proposed scheme	Text

Sou_E	Existing source	Existing water source from lookup table	Lookup table (eg borehole, reservoir)
Sou_F	Future source	Future water source from lookup table	Lookup table (eg borehole, reservoir)
WatNam_E	Existing source name	Name of existing source	Text
WatNam_F	Future source name	Name of future source	Text
Proj_Typ	Project type	Type of project from lookup table	Lookup table (eg MWIG, BIG)
SuppDate	Scheme supply date	Date of proposed intervention	Text
Treat	Treatment type	Existing treatment type from lookup table	Lookup table (eg WTP, sand filter)
WTP_Nam	WTP name	Name of water treatment plant	Text
Conn	Connection	Type of water connection from lookup table	Lookup table (eg yard, house, community standpipe)
Design_E	Existing design demand	Demand for which this scheme has been designed	Number (million m ³ p.a.)
LowDemandForecast	Demand Low	Low demand forecast	Number (million m ³ p.a.)
HighDemandForecast	Demand High	High demand forecast	Number (million m ³ p.a.)
ProbableDemand	Probable demand	Probable demand forecast	Number (million m ³ p.a.)
Supp_E	Existing supply	Current water supply capacity	Number (million m ³ p.a.)
CurrentWaterRequirements	Water requirements	Current water requirements	Number (million m ³ p.a.)
FutureWaterRequirements	Future water requirements	Future water requirements	Number (million m ³ p.a.)
Proj_ID	Project ID	ID of project if known	Text

HH_Low	Households low	Lowest estimate of households served	Number
HH_High	Households high	Highest estimate of households served	Number
Pop_Low	Population low	Lowest estimate of number of people	Number
Pop_High	Population high	Highest estimate of number of people	Number
Capturer	Capturer	Person who captured the area from lookup table	Lookup table (eg MHP Geospace, Mlungisi Dimba MMPDNA)
Sanitation	Type of sanitation scheme	Type of sanitation scheme from lookup table	Lookup table (eg septic tank, VIP)
Comments	Comments	General comments	Text
Assumptions	Assumptions	Assumptions made about existing infrastructure	Lookup table (eg Existing water scheme has enough capacity to be extended)
Assumptions_Other	Other Assumptions	Any other assumptions made about the area	Text
PopStats_Source	Population Statistics Source	The data source for the population statistics	Lookup table (eg Census 2011, Eskom 2011)
Source_Metadata	Metadata on water source	Information on whether the population data has been edited or verified	Lookup table (eg. Spatial calculation, Verified)
Connection_Metadata	Metadata on connection type	Information on whether the population data has been edited or verified	Lookup table (eg. Spatial calculation, Verified)
Completeness	Completeness of data	A percentage showing the number of fields populated per rectod	Number

SettlementType	Settlement Type	Settlement type (rural, urban etc) where available	Text
SanitationLOS	Sanitation Level of Service	The current sanitation level of service where data is available	Text

WATER PIPELINE ATTRIBUTES

Field Name	Alias	Description
Pipeline_Type	Pipeline type	Type of pipeline from lookup table
Project_Type	Project type	Project type from lookup table
Supply_Type	Supply type	Supply type from lookup table
Water_Source	Water source	Water source from lookup table
Capturer	Capturer	Data capturer from lookup table
Comments	Comments	General comments

WATER NODE ATTRIBUTES

Field Name	Alias	Description
Node_Type	Type of facility	Type of facility from lookup table
Capturer	Data capturer	Data capturer from lookup table
Comments	Comments	General comments

LOOK UP TABLES

DOMAIN NAME AND CODES	DESCRIPTION
Capturer	Name of data capturer
0	Not updated
1	Juan Wood (MMPDNA)
2	Petrus Buthelezi (MMPDNA)
3	Mlungisi Dimba (MMPDNA)
4	MHP GeoSpace
5	District Municipality
6	MMPDNA Data Capturers
7	MMPDNA Team 2
Connection	Water connection type
0	Unknown
1	Yard connection
2	House connection
3	Community standpipe
4	Jojo tank
5	Reservoir
Metadata	Metadata
Calculated	Calculated
Verified	Verified
Captured	Captured by MHP GeoSpace
Quality Assured	QA by MHP GeoSpace

PopStats_Source	Source of population stats
Eskom	Eskom household points 2011
Census	Stats SA Census 2011

Project_Type	Project Type
0	Unknown
1	BIG
2	Umgeni Water
3	MWIG
4	Umhlathuze Water
5	CMIP
6	MIG 1
7	MIG 2
8	MIG 3
9	MIG 4
10	MIG 5
Sanitation_Type	Type of Sanitation
0	Unknown
1	VIP
2	Septic tank
3	Chemical
4	Waterborne
5	None
Treatment_Type	Treatment Type
0	Unknown
1	WTP
2	Chlorination
3	Sand filter
4	Package plant
5	None
Water_Source	Water Source
0	Unknown
1	Local water scheme
2	Borehole
3	Water tanker
4	Regional water scheme
5	Spring
6	Abstraction
7	Reservoir
8	Water Works

Yes_No	Yes No
0	Unknown
1	Yes
2	No
Assumptions	Assumptions about water schemes
Capacity can be extended	Existing water scheme has enough capacity to be extended

Scheme to be upgraded	Existing water scheme has to be upgraded in order to have capacity to extend
Supplied with electricity	The area is fully supplied with electricity
Functional boreholes	All existing boreholes are functional
Raw water sources have capacity	Raw water source has enough capacity to abstract from
Other	Other assumptions
Node_Type	
0	Unknown
1	Reservoir
2	Pumpstation
3	Raw extraction
4	Water treatment works
5	Waste water treatment works
6	Package plant
7	Borehole
Pipeline_Type	
1	Bulk
2	Reticulation
0	Unknown

Annexure 2 – GIS Methodology

GIS METHODOLOGY

WATER SUPPLY FOOTPRINTS

- Settlement data (DWA settlements; Department of Rural Development and Land Reform settlements; Eskom household points) overlaid on aerial photography
- Polygons digitized around settlement clusters with outlying households being incorporated where possible
- Polygons captured over whole district, including areas with existing supply
- Fields added to attribute table as per Umgeni Water requirements
- Web mapping application developed so polygons could be edited, updated, created by users outside of the office environment

POPULATION STATISTICS

- Census 2011 data extracted using the SuperCross application from StatsSA
- Household counts calculated for each polygon using a spatial join between the demand polygons and the Eskom 2011 household points
- Population growth rate calculated by extrapolating the growth rate for each ward from 2001 to 2014 using census data from 2001 and 2011
- Growth rate applied to the household count to obtain figures for the highest possible household number in 2014
- Total population was divided by the number of households per sub-place to get the average household size per house per sub-place
- Household size data linked to demand areas (spatial join) and summarized to get the number of people in each demand area
- Growth rate (as calculated previously) applied to these numbers to reach a best possible approximated population figure for 2014 per demand area
- Water demand forecasts (high and low) calculated by using these population figures multiplied by the estimated water consumption appropriate to each settlement type as advised by the engineers in accordance with the Department of water Affairs standard.

CURRENT WATER INFORMATION

- All available water data from the municipalities – boreholes, reservoirs, springs, pipelines, water treatment works etc – added to ArcGIS project along with the demand area polygons
- Demand areas selected according to data falling within their boundaries (select by location tool) and attribute table updated accordingly
- Where no data was available from the municipality, the spatial information from Umgeni Water and the Department of Water Affairs was used in this query
- Additional data was received towards the end of the project for Amajuba, Ugu and uThukela District Municipalities requiring the spatial queries to be rerun and the attribute tables updated accordingly

CONCEPT DESIGNS AND COSTING


- All water infrastructure data and the water demand areas plotted on A1 maps at 1:20 000 scale
- Engineers produced concept designs hand drawn onto these maps
- Hard copy maps then scanned and georeferenced
- Concept designs digitized off the georeferenced scans

- Geodatabase with feature datasets for lines and points with available attribute information; domains used to reduce data capture time and possibility of errors
- Digitized data checked at map edges to ensure continuity of data
- All concept data (digitized) for each district merged to one dataset in the geodatabase
- Proposed water schemes given a unique ID by the engineers
- These ID captured into the GIS to link to the costing table from the engineers

METADATA

- Three geodatabases have been prepared:
 1. Base Data:
 - Roads, rivers, place names, administrative boundaries etc
 - Settlement data – Eskom household points
 - Cadastral data – urban and rural
 - Social facilities – health, education
 - Topography – 20m contours
 2. Infrastructure:
 - Existing pipelines, reservoirs, boreholes etc
 3. UAP:
 - Pipelines, standpipes, boreholes etc
 - Water supply footprints
- Metadata created for each dataset using ArcCatalog
- Data stored in WGS 1984


Annexure 3 – Planned Infrastructure Maps



**VULAMEHLO
LOCAL MUNICIPALITY**

**ALL WATER
INFRASTRUCTURE**

- LEGEND**
- Place Names
 - Conceptual Design (Features)**
 - Boroholo
 - Reservoir/Tank with Chlorination Unit
 - Elevated Tank
 - Water Treatment Works
 - Pump Station
 - Reservoir
 - Standpipe
 - Pumps
 - Reservoirs
 - Water Treatment Works
 - Wasto Water Treatment Works
 - Supply Source**
 - Boroholo
 - Dam
 - River
 - Spring
 - Conceptual Design (Pipelines)**
 - Existing and Planned Pipelines
 - Reticulation
 - Rising Main
 - Major Rivers
 - Minor Rivers
 - Roads**
 - National Roads
 - Provincial Roads
 - District Roads
 - Municipal Roads
 - Other Roads/Access
 - Water Demand Areas
 - Wards
 - Ugu District Municipality
 - Local Municipalities (2011)
 - District Municipalities (2011)




Disclaimer: These proposals are indicative only for planning purposes. These layouts do not necessarily reflect the long term planning by the Water Services Authority or Water Services Provider. The long term planning layouts are still in development by several of the Municipalities and were not yet available at the time of this report.

FOCUS
A Division of the ICrowe Property Group

Mott MacDonald
PDNA

MHP
GEOSPACE


cogta
Department:
Co-operative Governance and Traditional Affairs
PROVINCE OF KWAZULU-NATAL



**UMDONI
LOCAL MUNICIPALITY**

**ALL WATER
INFRASTRUCTURE**

- LEGEND**
- Place Names
 - Conceptual Design (Features)
 - Reservoir
 - Reservoir / Tank with Chlorination Unit
 - Elevated Tank
 - Water Treatment Works
 - Pump Station
 - Reservoir
 - Standpipe
 - Pumps
 - Reservoirs
 - Water Treatment Works
 - Waste Water Treatment Works
 - Supply Source
 - Boroholo
 - Dam
 - River
 - Spring
 - Existing and Planned Pipelines
 - Reticulation
 - Rising Main
 - Major Rivers
 - Minor Rivers
 - Roads
 - National Roads
 - Provincial Roads
 - District Roads
 - Municipal Roads
 - Other Roads/Access
 - Water Demand Areas
 - Wards
 - Ugu District Municipality
 - Local Municipalities (2011)
 - District Municipalities (2011)




Disclaimer: These proposals are indicative only for planning purposes. These layouts do not necessarily reflect the long term planning by the Water Services Authority or Water Services Provider. The long term planning layouts are still in development by several of the Municipalities and were not yet available at the time of this report.

FOCUS
A Division of the Crews Property Group

Municipalities PDNA
MHP
GEOSPACE

cogta
Department of Cooperative Governance and Traditional Affairs
PROVINCE OF KWAZULU-NATAL




UMZUMBE LOCAL MUNICIPALITY

ALL WATER INFRASTRUCTURE


LEGEND


- Place Names
- Conceptual Design (Features)
 - Borohoto
 - Reservoir/Tank with Chlorination Unit
 - Elevated Tank
 - Water Treatment Works
 - Pump Station
 - Reservoir
 - Standpipe
 - Pumps
 - / Reservoirs
 - Water Treatment Works
 - Wasto Water Treatment Works
- Supply Source**
 - Borohoto
 - Dam
 - Rivor
 - Spring
 - Existing and Plannod Pipelines
- Conceptual Design (Pipelines)**
 - Reticulation
 - Rising Main
 - Major Rivers
 - Minor Rivers
- Roads**
 - National Roads
 - Provincial Roads
 - District Roads
 - Municipal Roads
 - Other Roads/Access
- Wards**
 - Water Demand Areas
 - Wards
 - Ugu District Municipality
 - Local Municipalities (2011)
 - District Municipalities (2011)




0 2.5 5
Kilometres

Disclaimer: These proposals are indicative only for planning purposes. These layouts do not necessarily reflect the long term planning by the Water Services Authority or Water Services Provider. The long term planning layouts are still in development by several of the Municipalities and were not yet available at the time of this report.





Department:
Co-operative Governance and Traditional Affairs
PROVINCE OF KWAZULU-NATAL





UMZIWABANTU LOCAL MUNICIPALITY

ALL WATER INFRASTRUCTURE


LEGEND

- Place Names
- Conceptual Design (Features)
 - Boroholo
 - Reservoir / Tank with Chlorination Unit
 - Elevated Tank
 - Water Treatment Works
 - Pump Station
 - Reservoir
 - Standpipe
 - Pumps
 - Reservoirs
 - Water Treatment Works
 - Wasto Water Treatment Works
- Supply Source
 - Boroholo
 - Dam
 - River
 - Spring
- Existing and Planned Pipelines
 - Reticulation
 - Rising Main
 - Major Rivers
 - Minor Rivers
- Roads
 - National Roads
 - Provincial Roads
 - District Roads
 - Municipal Roads
 - Other Roads/Access
- Water Demand Areas
- Wards
- Ugu District Municipality
- Local Municipalities (2011)
- District Municipalities (2011)








Disclaimer: These proposals are indicative only for planning purposes. These layouts do not necessarily reflect the long term planning by the Water Services Authority or Water Services Provider. The long term planning layouts are still in development by several of the Municipalities and were not yet available at the time of this report.





A member of the City & Regional Group












Department
Co-operative Governance and Traditional Affairs
PROVINCE OF KWAZULU-NATAL

Copyright FOCUS;MM PDNA (Pty) Ltd; MHP GEOSPACE ; SIVUNO CONSULTING
Development of Universal Access Plan for Water Services in Ugu District Municipality

125




EZINGOLENI LOCAL MUNICIPALITY

ALL WATER INFRASTRUCTURE






LEGEND


- Place Names
- Conceptual Design (Features)**
- Borehole
- Reservoir/Tank with Chlorination Unit
- Elevated Tank
- Water Treatment Works
- Pump Station
- Reservoir
- Standpipe
- Pumps
- Reservoirs
- Water Treatment Works
- Wastewater Treatment Works
- Supply Source**
- Borehole
- Dam
- River
- Spring
- Existing and Planned Pipelines
- Conceptual Design (Pipelines)**
- Reticulation
- Rising Main
- Major Rivers
- Minor Rivers
- Roads**
- National Roads
- Provincial Roads
- District Roads
- Municipal Roads
- Other Roads/Access
- Water Demand Areas
- Wards
- Ugu District Municipality
- Local Municipalities (2011)
- District Municipalities (2011)




0 2.5 5
Kilometres

Disclaimer: These proposals are indicative only for planning purposes. These layouts do not necessarily reflect the long term planning by the Water Services Authority or Water Services Provider. The long term planning layouts are still in development by several of the Municipalities and were not yet available at the time of this report.



cogta
Department:
Co-operative Governance and Traditional Affairs
PROVINCE OF KWAZULU-NATAL




**HIBISCUS COAST
LOCAL MUNICIPALITY**

**ALL WATER
INFRASTRUCTURE**

LEGEND

- Placo Namos
- Conceptual Design (Features)
 - Boroholo
 - Reservoir/Tank with Chlorination Unit
 - Elevated Tank
 - Water Treatment Works
 - Pump Station
 - Reservoir
 - Standpipe
 - Pumps
 - Reservoirs
 - Water Treatment Works
 - Wastewater Treatment Works
- Supply Source
 - Boroholo
 - Dam
 - River
 - Spring
 - Existing and Planned Pipelines
- Conceptual Design (Pipelines)
 - Reticulation
 - Rising Main
 - Major Rivers
 - Minor Rivers
- Roads
 - National Roads
 - Provincial Roads
 - District Roads
 - Municipal Roads
 - Other Roads/Accross
- Water Demand Areas
 - Wards
 - Ugu District Municipality
 - Local Municipalities (2011)
 - District Municipalities (2011)



Disclaimer: These proposals are indicative only for planning purposes. These layouts do not necessarily reflect the long term planning by the Water Services Authority or Water Services Provider. The long term planning layouts are still in development by several of the Municipalities and were not yet available at the time of this report.

FOCUS
A Division of the Crowe Property Group

SIVUNO MHP
Mott MacDonold PDNA MHP
WAZZU GEOSPACE

cogta
Department: Co-operative Governance and Traditional Affairs
PROVINCE OF KWAZULU-NATAL

12. ACKNOWLEDGEMENT AND DISCLAIMER

This report was prepared by the consortium consisting of Focus, Mott Macdonald PDNA, MHP GeoSpace and Sivuno Consulting with the technical support from Zululand District Municipality under the direction and review from COGTA and Umgeni Water.

The information and data obtained in this report was obtained from Zululand District Municipality Infrastructure Development Plans (IDP's), Water Services Development Plans (WSDP) and mainly engagements with Zululand District Municipality staff.

Neither the consortium nor any of its employees assume any liability or responsibility for any third party use of any information discussed in this report.

The primary contact regarding questions or comments on this document is:

Department of Cooperative Governance and Traditional Affairs

Contact Person: Muzi Ngwane

Email address: muziwesipho.ngwane@misa.gov.za